



2011-12 Annual Water Quality Monitoring Plan

March 2011

Plan Details

Plan: Annual Water Quality Monitoring Plan 2011-12
TRIM Record Number: HW2006-1448/8/9.021
Author(s): Pam O'Donoghue
Document Version: Final

Document History and Status

Issue	Document Version	Date	Reviewed By	Approved By
1	Draft 1	11/2/2011	Bruce Cole / Darren Cleary	
2	Draft 2	23/2/2011	Philippe Porigneaux (NSW Health)	
3	Final	21/3/2011		Dean Taylor GMSO

TABLE OF CONTENTS

1.	STRATEGIC WATER QUALITY MONITORING	4
1.1	Source water monitoring	4
1.2	Operational monitoring	5
1.3	Customer based monitoring.....	5
1.4	Verification monitoring	5
1.5	Monitoring in response to incidents and emergencies	5
2	OPERATING LICENCE REQUIREMENTS	6
3	SOURCE WATER	7
3.1	Routine monitoring.....	7
3.2	Targeted, investigative and risk-based monitoring	13
4	PROCESS CONTROL AND OPERATIONAL MONITORING ..	14
5	CUSTOMER-BASED MONITORING	16
6	WATER QUALITY MONITORING IN RESPONSE TO INCIDENTS	18
7	VERIFICATION MONITORING	19
7.1	Background	19
7.2	Sampling frequency	19
7.3	Sample points to be representative of the system.....	20
7.4	Assessing compliance	23
7.4.1	Assessing compliance for Chichester, Grahamstown, Lemon Tree Passage and Anna Bay/Nelson Bay water supply systems	23
7.4.2	Assessing compliance for Gresford water supply system.....	24
7.5	Comprehensive program for sampling and analysis.....	25
7.5.1	Chichester, Grahamstown, Lemon Tree Passage and Nelson Bay / Anna Bay systems	25
7.5.2	Gresford Water Treatment Plant (WTP).....	27
7.5.3	Gresford distribution system	29
7.6	Laboratory testing and reporting processes	30
7.6.1	Quality assurance.....	30
7.6.2	Data verification and record keeping.....	30
8	DEFINITIONS, ACRONYMS, AND ABBREVIATIONS	31

9	REFERENCES	32
----------	-------------------------	-----------

10	ATTACHMENTS	33
-----------	--------------------------	-----------

TABLES

Table 1	Components of water quality monitoring and corresponding elements of the Framework	4
Table 2	Routine drinking water monitoring parameters for raw (bulk) water	8
Table 3	Routine drinking water monitoring parameters for Gresford raw water	12
Table 4	Risks to drinking water quality and corresponding targeted water quality monitoring	13
Table 5	On-line instrumentation at critical control points	14
Table 6	Populations and no. samples required in zones	20
Table 7	Distribution water quality sample points for 2011-12	21
Table 8	Key parameters and criteria used to assess drinking water quality compliance for 2011-12 – Chichester, Grahamstown, Lemon Tree Passage and Anna Bay/Nelson Bay zones	23
Table 9	Key parameters and criteria used to assess drinking water quality compliance for Gresford zone for 2011-12	24
Table 10	Routine drinking water quality parameters treated water – Chichester, Grahamstown, Lemon Tree Passage and Nelson Bay/Anna Bay zones	26
Table 11	Routine drinking water monitoring parameters for Gresford WTP treated water	27
Table 12	Routine analysis distribution system points at customers' water services – Chichester, Grahamstown, Lemon Tree Passage and Nelson Bay/Anna Bay zones	28
Table 13	Routine analysis distribution system – sample points at customers' water services – Gresford	29

FIGURES

Figure 1	SCADA diagram for Grahamstown water treatment plant	15
Figure 2	The Hunter Water data dashboard showing number of water quality complaints, by category, over the previous 7 days.	16

1. STRATEGIC WATER QUALITY MONITORING

Protection of public health by assuring the safety of drinking water is the primary objective of drinking water quality management and treatment.

The *2004 Australian Drinking Water Quality Guidelines (ADWG) Framework for the Management of Drinking Water Quality* (the Framework) integrates best practice and provides the basis for management of drinking water quality at Hunter Water Corporation (Hunter Water). The framework emphasises a preventative risk management approach for all steps in water supply from the water source to the consumer.

The Framework incorporates a strategic approach to water quality monitoring:

“The best assurance of drinking water safety is to develop a complete monitoring system which includes relevant monitoring aspects of research, operational performance, validation and verification...Essentially, a strategic water quality monitoring system involves an integrated program of source water, process control and event-driven monitoring when the system is being increasingly challenged, supplemented with verifying the effectiveness of distribution system prevention programs, and monitoring consumer satisfaction”

(Rizak and Hrudey 2007, p. 5.)

Hunter Water’s drinking water quality monitoring plan corresponds to the following elements of the Framework.

TABLE 1 Components of water quality monitoring and corresponding elements of the Framework

Monitoring Component	Framework Element	Element Description
Source Water Monitoring	Element 2	Assessment of drinking water supply system
Operational Monitoring	Element 4	Operational procedures and process control
Customer Based Monitoring	Element 4 Element 5	Operational procedures and process control Verification of drinking water quality
Verification Monitoring	Element 5	Verification of drinking water quality
Monitoring in response to incidents and emergencies	Element 6	Management of incidents and emergencies

1.1 Source water monitoring

Historical water quality data can assist in understanding source water characteristics and system performance. This can aid the identification of hazards and aspects of the drinking water supply system which requires improvement.

Trend analysis and control charts to monitor source water quality are used for recognising potential problems or hazards and the accumulation of any gradual changes or cumulative effects.

Source water quality monitoring builds on current knowledge and increases Hunter Water’s understanding of its supply systems.

1.2 Operational monitoring

Operational monitoring includes water quality monitoring to assess and confirm the performance of preventive measures. On-line operational monitoring of water quality parameters is a key component of process control and “real-time” management of drinking water quality. Data from operational monitoring is used as a trigger for corrective actions to improve drinking water quality. Examples include on-line monitoring for fluoride, chlorine residual, pH and turbidity.

1.3 Customer based monitoring

An effective customer complaint and response system closely linked to operations is an important component of preventive strategy for drinking water safety. Customer complaints are documented and investigated. A customer complaints system is in place to highlight and track unusual types or numbers of complaints.

1.4 Verification monitoring

Verification of drinking water quality provides an assessment of the overall performance of the system and the ultimate quality of drinking water being supplied to customers. The water quality verification monitoring plan includes monitoring at representative points throughout the supply system. All source waters, treatment processes, and distribution systems are routinely monitored for a range of parameters as recommended in the Australian Drinking Water Guidelines (ADWG) using a National Association of Testing Authorities (NATA) accredited laboratory testing program.

1.5 Monitoring in response to incidents and emergencies

Protocols for response to water quality incidents and emergencies include increased and strategic monitoring of water quality. Hunter Water has in place the capacity to sample and analyse water quality at short notice, and with minimum turnaround times.

2 OPERATING LICENCE REQUIREMENTS

Hunter Water delivers its services under an operating licence granted by the State Government and administered by the Independent Pricing and Regulatory Tribunal (IPART). The operating licence is the major customer protection instrument and prescribes standards of service that must be met in relation to water quality, continuity, pressure, sewer overflows and wastewater transportation.

Section 3.3 of the Hunter Water Corporation Operating Licence 2007-2012 sets out the requirements for water quality monitoring:

3.3 Water Quality – Monitoring

3.3.1 Hunter Water must prepare, to the satisfaction of NSW Health, a comprehensive annual water quality monitoring plan (Annual Water Quality Monitoring Plan) for the Water Supply System by 31 March each year, for the duration of the Licence. This Annual Water Quality Monitoring Plan must:

- (a) include monitoring of Bulk Water and Drinking Water quality and details of laboratory testing and reporting processes to ensure quality control;*
- (b) have regard to the concepts of good practice set out in the Australian Drinking Water Guidelines and apply those concepts as specified by NSW Health;*
- (c) for Bulk Water, include a list of characteristics that will be monitored to identify potential hazards with the water supply, or a change in water quality;*
- (d) include targeted, investigative and event-based monitoring; and*
- (e) include monitoring for any other water characteristic nominated by NSW Health.*

3.3.2 Monitoring under the Annual Water Quality Monitoring Plan must be undertaken for the period from the Commencement Date to 30 June 2008 and after that for each subsequent financial year.

3.3.3 The sampling frequency and the locations chosen for the Drinking Water quality monitoring should be representative of the quality of Drinking Water supplied to Consumers.

3.3.4 Hunter Water must provide IPART with a copy of the Annual Water Quality Monitoring Plan as soon as possible after it is agreed with NSW Health. Hunter Water must make a copy of that plan available to the public after it has been provided to IPART.

3.3.5 If Hunter Water and NSW Health cannot agree on the Annual Water Quality Monitoring Plan, the views of NSW Health will prevail and Hunter Water must accept the Annual Water Quality Monitoring Plan determined by NSW Health.

3 SOURCE WATER

Routine as well as targeted and investigative monitoring is undertaken at source waters.

This water quality data is analysed and incorporated into the risk assessment process. Trend analysis and control charts are used for recognising potential problems or hazards and the accumulation of any gradual changes or cumulative effects.

Analysis of source waters contributes to the framework principle “know your system”, that is, the data aids in understanding Hunter Water’s sources and assessing the risks.

3.1 Routine monitoring

Under the operating licence, the water quality monitoring plan for bulk water must include a list of characteristics that will be monitored to identify potential hazards with the water supply, or a change in water quality.

Table 2 on the following page sets out routine drinking water quality parameters for raw (bulk) waters for Chichester, Grahamstown, Tomago, Lemon Tree Passage, and Nelson Bay/Anna Bay Sources. Table 3 on page 12 sets out routine drinking water quality parameters for raw water for Gresford.

Sampling frequencies for most parameters are at least equal to the frequency recommended in Table 10.7 of the ADWG (ADWG 2004, p.10.16). The last column of Table 2 indicates characteristics that are recommended in the ADWG for monitoring in raw waters.

Where the recommended sampling frequency is “annually if at all”, Hunter Water has adopted (as a minimum) a default frequency of once every 5 years.

**TABLE 2 Routine drinking water monitoring parameters for raw (bulk) water –
Chichester, Grahamstown, Tomago, Lemon Tree Passage, and Nelson Bay/Anna
Bay Sources**

Parameter	Frequency	No. of locations	Analysis by:	ADWG Table 10.7
pH	Daily	6	HWA Water Treatment	√
Turbidity	Daily	6	HWA Water Treatment	√
Fluoride	Daily at Grahamstown, Dungog and Tomago.	6	HWA Water Treatment	√
Iron	Weekly at Lemon Tree Passage, Anna Bay and Nelson Bay			√
Manganese				√
Aluminium	Weekly	6	HWA Water Treatment	
Cyanobacteria	Weekly, or Twice Weekly if > 2000 cells/ml of a potentially toxic species is detected	4 at Grahamstown and 7 at Chichester	HWA	√
<i>E. coli</i>	Weekly	6	HWA	√
Total Coliforms	Weekly	6	HWA	√
Heterotrophic Plate Count	Weekly	2	HWA	√
Ammonia	Quarterly	6	HWA	
Nitrites	Quarterly	6	HWA	
Nitrates	Quarterly	6	HWA	
Cryptosporidium	Quarterly at Lemon Tree Passage, Nelson Bay and Anna Bay, Fortnightly Grahamstown and Chichester	6	HWA	
Giardia	Quarterly at Lemon Tree Passage, Nelson Bay and Anna Bay, Fortnightly Grahamstown and Chichester	6	HWA	
2-Methylisoborneol (MIB)	Weekly	Grahamstown and Chichester ¹	HWA	
Geosmin		Grahamstown and Chichester ¹	HWA	
Aldrin	Monthly	6	DAL	√
Amitrole	Monthly	6	ALS	√
Atrazine	Monthly	6	DAL	√
Chlordane	Monthly	6	DAL	√
Chlorfenvinphos	Monthly	6	DAL	√
2,4-D	Monthly	6	DAL	√
DDT	Monthly	6	DAL	√
Dieldrin	Monthly	6	DAL	√
Diuron	Monthly	6	DAL	√
Endosulphan	Monthly	6	DAL	√
Fosamine	Monthly	6	DAL	√
Heptachlor	Monthly	6	DAL	√

¹ Sampling for MIB and Geosmin for Chichester source is undertaken in Dungog filtered water, ie after flocculation and filtration, but before disinfection, fluoridation and pH and alkalinity correction
HW2006-1448 8 9.022 Report - Water Quality Monitoring Plan 2011_12 Website Version.DOC
Page 8

Parameter	Frequency	No. of locations	Analysis by:	ADWG Table 10.7
Lindane	Monthly	6	DAL	√
Molinate	Monthly	6	DAL	√
Pichloram	Monthly	6	DAL	√
Propiconazole	Monthly	6	DAL	√
Temephos	Monthly	6	ALS	√
Polychlorinated Biphenyl (PCB)	Quarterly	6	ALS	
Glyphosate	Quarterly	6	ALS	√
Metsulfuron-methyl	Quarterly	6	ALS	√
Antimony	Quarterly	6	HWA	
Arsenic	Quarterly at Grahamstown and Chichester, weekly at Tomago, Lemon Tree Passage, Anna Bay, Nelson Bay	6	HWA	√
Barium	Quarterly	6	HWA	√
Beryllium	Quarterly	6	HWA	√
Boron	Quarterly	6	ALS	√
Cadmium	Quarterly	6	HWA	
Chromium	Quarterly	6	HWA	
Copper	Quarterly	6	HWA	
Cyanide	Quarterly	6	ALS	
Iodide	Quarterly	6	AWQC	
Lead	Quarterly	6	HWA	
Mercury	Quarterly	6	HWA	√
Nickel	Quarterly	6	HWA	
Molybdenum	Quarterly	6	HWA	√
Selenium	Quarterly	6	HWA	√
Sodium	Quarterly	6	HWA	
Sulphide	Quarterly	6	HWA	
Tin	Quarterly	6	HWA	√
Zinc	Quarterly	6	HWA	
Pathogenic Thermophilic and Nuisance Mesophilic Amoeba	Annually	6	AWQC	
Beryllium	Once every five years	6	HWA	√
Silver	Quarterly	6	HWA	√
Benzene	Once every five years at Lemon Tree Passage, Anna Bay, Nelson Bay and Chichester / Annually at Grahamstown and Tomago	6	SGS	√
Chlorobenzene		6	SGS	√
Dichlorobenzenes 1,2-dichlorobenzene 1,3-dichlorobenzene 1,4-dichlorobenzene		6	SGS	√

Parameter	Frequency	No. of locations	Analysis by:	ADWG Table 10.7
Dichloroethanes 1,1-dichloroethanes 1,2-dichloroethanes	Once every five years at Lemon Tree Passage, Anna Bay, Nelson Bay and Chichester / Annually at Grahamstown and Tomago	6	SGS	√
Dichloroethenes 1,1-dichloroethenes 1,2-dichloroethenes		6	SGS	√
Dichloromethane (methylene chloride)		6	SGS	√
Ethylbenzene		6	SGS	√
Ethylenediamine tetracetic acid (EDTA)		6	SGS	√
Hexachlorobutadiene		6	SGS	√
Nitrilotriacetic acid		6	SGS	√
Organotins Dibutyltin Tributyltin		6	Leeder Consulting	√
Styrene		6	SGS	√
Tetrachloroethene		6	SGS	√
Toluene		6	SGS	√
Trichlorobenzenes (total)		6	SGS	√
1,1,1-Trichloroethane		6	SGS	√
Trichloroethylene (TCE)		6	SGS	√
Vinyl Chloride	6	SGS	√	
Radiological - Gross alpha & beta activity	Once every two years for groundwater (Anna Bay, Nelson Bay Lemon Tree Passage and Tomago), once every five years for surface water (Grahamstown and Dungog)	6	ANSTO	√

ALS = Australian Laboratory Services (Sydney)

ANSTO = Australian Nuclear Science and Technology Organisation (Lucas Heights)

DAL = Department of Analytical Laboratories (Lidcombe)

AWQC = Australian Water Quality Centre (SA)

SGS = SGS Laboratories Melbourne

HWA = Hunter Water Australia Laboratories

HWA Water Treatment = Hunter Water Australia Process and Operations

i.e. analysis is carried out at Water Treatment Plants

(Hunter Water Australia is a fully owned subsidiary of Hunter Water Corporation)

Notes on raw (bulk) water testing

The six raw water sources referred to previously in Table 2 are:

- Chichester Dam;
- Grahamstown Dam;
- Tomago bores;
- Lemon Tree Passage bores;
- Anna Bay bores; and
- Nelson Bay bores.

The six locations nominated represent each of the raw water sources excluding the Gresford water supply system.

For Cyanobacteria, samples are only taken from the surface water supplies. The samples are collected from Chichester Dam (at 6 depths and at off take), Williams River at Boags Hill (off take for pumping to Grahamstown) and at three locations within Grahamstown Dam and Grahamstown Dam raw.

Particle counting is undertaken at Dungog and Grahamstown Water Treatment Plants.

Weekly monitoring for the taste and odour compounds 2-Methylisoborneol (MIB) and Geosmin is undertaken at Grahamstown raw and Dungog filtered (i.e. after coagulation and filtration, and before fluoridation, disinfection, pH and alkalinity correction). During taste and odour events, the frequency of analysis may be increased.

Monitoring for Cryptosporidium and Giardia is undertaken fortnightly for Dungog and Grahamstown raw waters, and quarterly for Tomago, Lemon Tree Passage, Anna Bay and Nelson Bay raw waters. The corresponding treated water is analysed if Cryptosporidium or Giardia are detected at any level in the raw water. Note that treated surface waters from Chichester and Grahamstown are also analysed for Cryptosporidium and Giardia quarterly (even if not detected in the raw water).

For “organics other than disinfection by-products” the ADWG recommend sampling “*monthly if persistent, otherwise event-related*”. None of Hunter Water’s sources are subject to persistent organic contamination. However, as the Grahamstown and Tomago water sources are potentially more susceptible to organic contamination due to land use within the catchments, sampling is undertaken for these sources on an annual basis. For the remaining four sources, as the risk of organic contamination is lower, sampling is undertaken once every five years.

Routine source water quality monitoring for the Gresford water supply is shown in Table 3.

TABLE 3 Routine drinking water monitoring parameters for Gresford raw water

Parameter	Frequency	No. of locations	Analysis by:
<i>E.coli</i>	Weekly	1	HWA
Total Coliforms	Weekly	1	HWA
Temperature	Weekly	1	HWA
pH	Weekly	1	HWA
Turbidity	Weekly	1	HWA
Calcium	Fortnightly	1	HWA
Blue-Green Algal Analysis	Weekly (from Dec to Feb inclusive)	2 (Allyn and Paterson)	HWA
Cryptosporidium & Giardia	Six-Monthly	2 (Allyn and Paterson)	HWA
Total organic carbon	Fortnightly	2 (Allyn and Paterson)	HWA
Dissolved organic carbon	Fortnightly	2 (Allyn and Paterson)	HWA
Alkalinity	3 times a week	1 (RWT)	HWA Water Treatment
Colour True and Apparent	3 times a week	1 (RWT)	HWA Water Treatment
Conductivity	3 times a week	1 (RWT)	HWA Water Treatment
Iron (total and soluble)	Weekly	1 (RWT)	HWA Water Treatment
Manganese (total and soluble)	Weekly	1 (RWT)	HWA Water Treatment
Aluminium	3 times a week	1 (RWT)	HWA Water Treatment

HWA = Hunter Water Australia Laboratories

HWA Water Treatment = Hunter Water Australia Process and Operations

i.e. analysis is carried out at Water Treatment Plants

(Hunter Water Australia is a fully owned subsidiary of Hunter Water Corporation)

3.2 Targeted, investigative and risk-based monitoring

Hunter Water's risk assessment processes use an approach which identifies and rectifies sources of risk rather than simply measuring and reporting water quality. This approach in collecting data increases understanding of the system and is considered industry best practice.

Routine monitoring, as set out the ADWG, incorporates a "generic" risk-based component. For example, the risk from pathogens feature as high on most risk assessments for drinking water quality systems and as a result, the frequency of testing for the indicator bacteria *E coli* is also high in the routine monitoring program.

"Event-based" monitoring during rainfall events has been undertaken at Campvale Canal as the canal drains water from a semi-urban catchment to Grahamstown Dam. This part of the catchment was identified during risk assessment as a potential risk of increased pathogens and pesticides particularly during rainfall events.

This monitoring plan has been established to increase Hunter Water's understanding of the supply system and supports the collection of water quality data that adds value to the existing body of knowledge from catchment to tap. These monitoring programs aim to fill in knowledge gaps identified through the Framework's hazard identification and risk assessment process.

Risks have been characterised in detail under the Framework, however, the broad categories of risk for Hunter Water's water supplies include:

- Pathogens;
- Blue-green algae (for surface storages);
- High Turbidity; and
- Chemicals (from natural geology, land use within catchment, pesticides, spills and water treatment chemicals).

Examples of risks identified and corresponding targeted monitoring are outlined in Table 4.

TABLE 4 Risks to drinking water quality and corresponding targeted water quality monitoring

Risk to Drinking Water Quality	Targeted Water Quality Monitoring
Pathogens, including bacteria, viruses, protozoa	<i>E.coli</i> , Cryptosporidium, Giardia and Amoeba (summer)
Blue-Green algal risks	Increased sampling frequency, speciation, and toxicity / Taste and Odour analysis as concentrations of BGA increase in line with BGA contingency plan
Arsenic, Manganese, Iron in Tomago source	Weekly analysis of Fe, Mn and As at individual Tomago stations while operating
Potential impact of Salt Ash Air Weapons Range	Quarterly Analysis for heavy metals at bore stations downstream of this site
Campvale Canal wet weather inflows to Grahamstown Dam	Event-based monitoring for nutrients, <i>E. coli</i> , cryptosporidium and giardia

4 PROCESS CONTROL AND OPERATIONAL MONITORING

Hunter Water uses monitoring protocols for the operational performance of its water supply system including the selection of operational parameters and criteria and the routine analysis of results. These include the monitoring of key parameters such as turbidity, pH, colour, iron, manganese, aluminium, copper, lead, zinc, fluoride, chlorine and trihalomethanes (THMs).

A critical control point is an activity, procedure or process at which control can be applied and which is essential to prevent a hazard or reduce it to an acceptable level. Critical control points are monitored throughout the system as part of Hunter Water's process control strategy. The collective effect of the target criteria and critical limits at all identified control points can consistently and effectively control all significant hazards.

Monitoring of key parameters in water sourced from raw water storages is undertaken to identify possible sources of contamination. Hunter Water also uses continuous on-line monitoring equipment for the monitoring of target criteria and critical limit parameters wherever possible, particularly at the most important control points. This is carried out via telemetered Supervisory Control and Data Acquisition (SCADA) systems, Programmable Logic Controller (PLC), water quality sampling results, catchment observation reports and treatment plant operational spreadsheets. This operational data is collected and monitored in a form that allows rapid detection of trends and can act as a trigger for the correction of exceedances in treatment processes.

A planned sequence of measurements and observations throughout the supply system is used to assess and confirm the performance of preventive measures already in place. Hunter Water uses timely monitoring for operational parameters where continuous on-line monitoring is not possible or necessary. These include regular inspections of the catchments and reservoirs and monitoring of surrogate water quality parameters. Operational surrogates are another strategy that Hunter Water uses to monitor overall water treatment performance. These parameters include turbidity, chlorine residual, flow, rainfall events, pH, particle counts and conductivity.

On-line instrumentation used to monitor treated water quality at critical control points is shown in the following table.

TABLE 5 On-line instrumentation at critical control points

Location / Instrument	Chlorine analyser	pH meter	Turbidity meter	Fluoride analyser
Chichester Dam	√		√	
Dungog WTP	√	√	√	√
Buttai Chlorinator	√			
Grahamstown WTP	√	√	√	√
North Lambton Chlorinator	√			
Toronto Chlorinator	√			
Cardiff Chlorinator	√			
Lemon Tree Passage WTP	√	√	√	√
Anna Bay WTP	√	√	√	√
Nelson Bay WTP	√	√		√
Gresford WTP	√	√	√	

Data from on-line instruments is monitored 24 hours a day with alarms to alert the operator when an alarm limit has been exceeded to allow appropriate corrective action taken.




FIGURE 1 SCADA diagram for Grahamstown Water Treatment Plant

Other examples of on-line monitoring for operational control include on-line monitoring of rainfall in the Chichester catchment and turbidity at the dam. Due to increased solids loading on the filters, flow through Dungog Water Treatment Plant needs to be reduced during periods of elevated turbidity. Rainfall and turbidity data provides an early warning, or trigger, to reduce flow through the plant.

Various processes are used to ensure that any potentially adverse monitoring results are rapidly notified to operational staff authorised to initiate corrective action. These include Water Treatment Plant spreadsheets, automated alarms, data exception emails, as well as laboratory non-conformance procedures.

Hunter Water sets target criteria that are more stringent than critical limits and has in place procedures to ensure that the operational monitoring (process monitoring) is implemented effectively.

5 CUSTOMER-BASED MONITORING

Hunter Water undertakes its customer-based monitoring on a continual basis which includes a process for recording all customer water quality complaints and the actions undertaken in response to these complaints. Routine water quality complaints such as dirty water complaints that require a simple follow-up (e.g. flushing) are recorded in the Assets Operations Maintenance System (AOMS). Complaints that require more detailed follow-up (e.g. ongoing water quality problems) are dealt with under the Complaint Management System.

Hunter Water responds to customer water quality complaints based on standard operating procedures. These procedures include a clear definition of authorities and responsibilities.

A daily review of water quality monitoring results is made possible using internal data management systems. Figure 2 shows a screen shot of the “Hunter Water Systems Performance Dashboard.”

HWC Systems Performance Dashboard											
Indicator	District	Period (click for details)							Limit		Period Frequency
		-6	-5	-4	-3	-2	-1	C	Low	High	
Sewer Gravity Main Break	A	0	0	0	0	0	0	0	0	1	1 Day(s)
Sewer Odour	A	1	0	0	0	0	2	0	0	0	1 Day(s)
Sewer Rising Main Breaks	A	0	0	0	0	0	0	0	0	0	1 Day(s)
Sewer Storm Surcharge	A	6	1	0	0	0	0	0	0	2	1 Day(s)
Sewer Surcharge - All	A	6	16	8	5	14	9	0	0	10	1 Day(s)
Sewer Surcharge - East 1	2	0	2	0	0	1	2	0	0	4	1 Day(s)
Sewer Surcharge - East 2	3	2	5	2	2	2	1	0	0	4	1 Day(s)
Sewer Surcharge - East 3	4	2	5	3	2	2	3	0	0	4	1 Day(s)
Sewer Surcharge - West 1	5	1	0	3	1	4	3	0	0	4	1 Day(s)
Sewer Surcharge - West 2	6	0	3	0	0	1	0	0	0	4	1 Day(s)
Sewer Surcharge - West 3	7	1	1	0	0	4	0	0	0	4	1 Day(s)
Vacuum Sewer Problem - All	A	0	0	0	0	0	0	0	0	2	1 Day(s)
Water Breaks	A	5	6	2	0	5	4	0	0	5	1 Day(s)
Water Breaks - Month (Calendar)	A	97	98	88	110	95	128	126	0	165	1 Calendar Month(s)
Water Breaks - Month (Rolling)	A	97	102	85	107	106	99	169	100	165	1 Rolling Month(s)
Water Breaks - Year (Financial)	A	1900	2032	1735	1427	1578	1561	863	0	1980	1 Financial Year(s)
Water Breaks - Year (Rolling)	A	2075	1817	1967	1652	1499	1476	1469	1000	1980	1 Rolling Year(s)
Water Low Pressure	A	0	0	0	0	0	0	0	0	3	1 Day(s)
Water Quality - Air/White	A	1	0	0	0	0	0	0	0	3	1 Day(s)
Water Quality - Chlorine	A	0	0	0	0	0	0	0	0	1	1 Day(s)
Water Quality - Dirty Water	A	1	2	0	0	1	2	0	0	3	1 Day(s)
Water Quality - Health	A	0	0	0	0	0	0	0	0	0	1 Day(s)
Water Quality - Other	A	0	0	0	0	0	1	0	0	3	1 Day(s)
Water Quality - Taste/Odour	A	0	0	0	0	2	0	0	0	3	1 Day(s)

FIGURE 2 Hunter Water data dashboard showing number of water quality complaints, by category, over the previous 7 days.

The dashboard shows numbers of water quality complaints over the seven days, by category of complaint. The dashboard can act as a trigger for further investigation or operational response. For example, during a taste and odour event, feedback from customers may be used to trigger Powdered Activated Carbon (PAC) dosing. Feedback from customers can, at times, be quicker than laboratory analysis of the taste and odour compounds Methylisoborneol (MIB) and geosmin.

Daily taste testing of surface water is also undertaken by suitably qualified operators. These results are evaluated and exceptions may trigger further investigation or operational response

6 WATER QUALITY MONITORING IN RESPONSE TO INCIDENTS

Hunter Water ensures that appropriate water quality monitoring and assessment is completed in response to water quality incidents should they occur. Sampling and analysis of affected, or potentially affected, areas of the water supply system is done as soon as any situation is assessed with results required in the fastest possible turnaround time.

Procedures for corrective actions in response to water quality monitoring non-conformances are used to manage all such events and provide clear definitions of roles and responsibilities, including any notification requirements.

The water quality exception reporting procedures are centrally located on the Hunter Water intranet site. Hunter Water operations staff are trained in these procedures.

Hunter Water has developed contingency and emergency response plans including procedures for response to water quality incidents. Simulated emergency management exercises are conducted on a regular basis to ensure key staff familiarity with the required protocols. Hunter Water has involved NSW Health in understanding of potential incidents and emergencies and in developing response plans.

7 VERIFICATION MONITORING

7.1 Background

“Verification of drinking water quality provides an assessment of the overall performance of the system and the ultimate quality of drinking water being supplied to customers.

... Verification monitoring provides

- a useful indication of problems within the water supply system (particularly the distribution system) and the necessity for any immediate short-term corrective actions or incident and emergency response*
- confidence for consumers and regulators regarding the quality of the water supplied”*

(ADWG 2004, p. 3-19)

Section 10 of ADWG *Monitoring for Specific Characteristics in Drinking Water* provides guidance on drinking water quality monitoring. Routine water quality monitoring is proposed to be undertaken by Hunter Water during 2011-12 in line with ADWG recommendations.

In addition to these routine samples Hunter Water will respond to specific water quality incidents with additional sampling targeted to identify levels and extent of specific water quality parameters as well as collecting data to identify trends.

Hunter Water currently has sixty-eight (68) licence sample points located throughout the distribution system for routine monitoring. The sample points are listed in Table 7 and the location of the points is shown on *Attachment 1: Plan Showing Water Quality Sample Points and Water Supply Zones*. The set of sampling points used for routine monitoring of water quality have been selected to be representative of the distribution system as a whole.

7.2 Sampling frequency

The ADWG Table 10.2 (ADWG 2004, p.10-5) sets out the recommended sampling frequency for microbiological monitoring. The sampling frequency is determined based on the population served. In assessing the number of samples to be collected, the water supply system is divided into monitoring zones as recommended in the ADWG outlined in Section 9.6.2 (ADWG 2004, p 9.6).

This effectively means that more samples are collected and analysed than would be collected if the number of samples was based on the total population.

Table 6 on the following page details the population and number of samples required in each zone.

TABLE 6 Populations and no. samples required in zones

ZONE	ESTIMATED 2010 POPULATION	NO. OF SAMPLES REQUIRED PER FORTNIGHT *	NO. SAMPLES PER FORTNIGHT** (SHOWN IN TABLE 7)
Grahamstown	370,628	26	36
Chichester	130,251	14	18
Lemon Tree Passage	7,536	3	6
Nelson Bay / Anna Bay	25,059	5	6
Gresford	331	2	2
TOTAL	533,805	50	68

* as set out in ADWG Table 10.2 (ADWG 2004, p.10-5)

** Note that fortnightly sampling is undertaken on a “week-about” basis, i.e. weekly sampling is undertaken.

7.3 Sample points to be representative of the system

ADWG (2004, p. 9-8) states that:

“The distribution of sample points throughout the system, including the extremities, must reflect the numbers of people supplied by the different parts of the system, especially for systems drawing on surface water. For instance, if five percent of consumers are serviced by distribution loops, then five percent of samples should be taken from distribution loops.”

The majority of customers within Hunter Water’s area of operations are serviced by a network of distribution mains.

“Dead-end” mains can be differentiated from other, continuous components of the distribution system. An estimate of the number of Hunter Water’s customers connected to dead-end supply mains has been calculated as outlined below:

Number of dead end mains is estimated at 4,600, counted from an overall facility information system (FIS) map of Hunter Water’s water mains. The average number of connections to each dead-end main is estimated at 6. The total number of properties connected to water at 30 June 2009 was 221,694. The number of properties connected to dead end mains (i.e. 6 x 4,600) therefore equates to around 13% of the total properties. Therefore, if the number of proposed fortnightly sample points is 68, then 8 of these should be located at dead-end mains. These should also be distributed spatially within the system.

The proposed 68 distribution system sample point locations is shown in Table 7, and of these, 9 are located at dead ends (as shown in Table 7).

TABLE 7 DISTRIBUTION SYSTEM WATER QUALITY SAMPLE POINTS FOR 2011-12

No	Sample Point	Dead End Main?	Zone
1	Hamilton	No	Grahamstown
2	Tighes Hill	No	Grahamstown
3	Lambton	No	Grahamstown
4	Adamstown	No	Grahamstown
5	Georgetown	No	Grahamstown
6	Tomago	No	Grahamstown
7	New Lambton	No	Grahamstown
8	Newcastle	Dead End	Grahamstown
9	Hamilton	No	Grahamstown
10	Merewether	No	Grahamstown
11	Birmingham Gardens	No	Grahamstown
12	Stockton	No	Grahamstown
13	Waratah West	Effectively a dead end: located near a shut zone valve	Grahamstown
14	Old Raymond Terrace Office	No	Grahamstown
15	Medowie	Dead End	Grahamstown
16	Rankin Park	No	Grahamstown
17	Wangi	No	Grahamstown
18	Belmont	No	Grahamstown
19	Swansea	No	Grahamstown
20	Balcolyn	No	Grahamstown
21	Warners Bay	No	Grahamstown
22	Edgeworth	Dead End	Grahamstown
23	Mt Hutton	No	Grahamstown
24	Cardiff	No	Grahamstown
25	Eleebana	No	Grahamstown
26	Toronto	No	Grahamstown
27	Morisset	No	Grahamstown
28	Caves Beach	No	Grahamstown
29	West Wallsend	No	Grahamstown
30	Redhead	No	Grahamstown
31	Charlestown	No	Grahamstown
32	Dudley	No	Grahamstown
33	Garden Suburbs	No	Grahamstown
34	Redhead	No	Grahamstown
35	Tingira Heights	Dead End	Grahamstown
36	Maitland	No	Chichester
37	East Maitland	No	Chichester
38	Thornton	No	Chichester
39	Kurri	No	Chichester
40	Bellbird	Dead End	Chichester
41	Pelaw Main	No	Chichester
42	Cessnock	No	Chichester
43	Heddon Greta	Dead End	Chichester
44	Metford	No	Chichester
45	Tarro	No	Chichester
46	Rutherford	No	Chichester

No	Sample Point	Dead End Main?	Zone
47	Branxton	No	Chichester
48	Tanilba Bay	No	Lemon Tree Passage
49	Karuah	No	Lemon Tree Passage
50	Nelson Bay	No	Nelson Bay / Anna Bay
51	Fingal Bay	No	Nelson Bay / Anna Bay
52	Soldiers Point	No	Nelson Bay / Anna Bay
53	Boat Harbour	Dead End	Nelson Bay / Anna Bay
54	Maryland	No	Grahamstown
55	Anna Bay	No	Nelson Bay / Anna Bay
56	Shoal Bay	No	Nelson Bay / Anna Bay
57	Lemon Tree Passage	No	Lemon Tree Passage
58	Seaham	No	Chichester
59	Lemon Tree Passage	Dead End	Lemon Tree Passage
60	Lemon Tree Passage	No	Lemon Tree Passage
61	Tanilba Bay	No	Lemon Tree Passage
62	Gresford	No	Gresford
63	Gresford	No	Gresford
64	Paterson	No	Chichester
65	Vacy	No	Chichester
66	Dungog	No	Chichester
67	Dungog	No	Chichester
68	Clarence Town	No	Chichester

The locations of the sample points are shown on:

Attachment 1: Plan showing water quality sample points and water supply zones

7.4 Assessing compliance

7.4.1 Assessing compliance for Chichester, Grahamstown, Lemon Tree Passage and Anna Bay/Nelson Bay water supply systems

Assessing performance for compliance purposes will be carried out on a corporate and water quality zone basis for 2011-12 for key parameters using the assessment methods specified in the ADWG for microbiological, physical and chemical parameters respectively. Zones are based on areas supplied by Water Treatment Plants.

Key parameters and criteria used to assess drinking water quality compliance for 2011-12 for Chichester, Grahamstown, Lemon Tree Passage and Anna Bay/Nelson Bay zones are shown below.

TABLE 8 Key parameters and criteria used to assess drinking water quality compliance for 2011-12 – Chichester, Grahamstown, Lemon Tree Passage and Anna Bay/Nelson Bay zones.

<i>Parameter</i>	<i>Microbiological / Physical / Chemical</i>	<i>Health-Related or Aesthetic</i>	<i>Guideline Value</i>	<i>Method of Assessing Compliance*</i>
<i>E. coli</i>	Microbiological	Health	At least 98% of scheduled samples contain 0 CFU per 100 ml	At least 98% of scheduled samples contain 0 CFU per 100 ml
pH	Physical	Aesthetic	6.5 to 9.2	The upper bound of the 95% confidence interval for the mean should be less than the guideline value
True colour			< 25 HU	
Turbidity			< 5 NTU	
Aluminium	Chemical	Aesthetic	< 0.2 mg/L	The upper bound of the 95% confidence interval for the 95 th percentile should be less than the guideline value
Iron			< 0.3 mg/L	
Zinc			< 3 mg/L	
Chlorine		Health	< 5 mg/L	
Copper			< 1 mg/L	
Lead			< 0.01 mg/L	
Manganese			< 0.1 mg/L	
Trihalomethanes		<0.25 mg/L		
Fluoride		< 1.5 mg/L		

* Assessing performance for compliance purposes will be carried out on a **corporate** and **zone** basis for all key compliance parameters

7.4.2 Assessing compliance for Gresford water supply system

The ADWG (2004, p 10-14) advise that:

“Monitoring of small water supplies should be based on the principle that it is much more effective to test for a narrow range of key characteristics as frequently as possible, supplementing this with sanitary inspection, than to conduct comprehensive but lengthy (and possibly largely irrelevant) analyses less often. In addition to health-related characteristics, small communities need to include other analyses relevant to the operation and maintenance of water treatment and distribution systems.

As a minimum, small community supplies should be monitored for the four characteristics that best establish the hygienic state of the water and the potential for other problems to occur:

- *indicator microorganisms*
- *disinfectant residual*
- *pH*
- *turbidity.”*

In line with this recommendation, key parameters and criteria used to assess drinking water quality for compliance purposed for Gresford zone during 2011-12 are in Table 9.

TABLE 9 Key parameters and criteria to be used to assess drinking water quality compliance for Gresford zone for 2011-12

Parameter	Microbiological / Physical / Chemical	Health-Related or Aesthetic	Guideline Value	Method of Assessing Compliance*
<i>E. coli</i>	Microbiological	Health	At least 98% of scheduled samples contain <1 CFU per 100 ml	At least 98% of scheduled samples contain 0 CFU per 100 ml
pH	Physical	Aesthetic	6.5 to 9.2	The upper bound of the 95% confidence interval for the mean should be less than the guideline value
Turbidity			< 5 NTU	
Chlorine	Chemical	Health	< 5 mg/L	The upper bound of the 95% confidence interval for the 95 th percentile should be less than the guideline value

7.5 Comprehensive program for sampling and analysis

A comprehensive program of sampling and analysis for health and aesthetic water quality parameters is proposed to be undertaken as recommended in ADWG:

- in raw waters;
- within the distribution system; and
- in treated waters at water treatment plants.

The number of sampling locations and frequency of sampling for health and aesthetic parameters to be tested are shown in tables 2,3,10,11,12 and 13 for raw, treated and distribution system monitoring.

7.5.1 Chichester, Grahamstown, Lemon Tree Passage and Nelson Bay / Anna Bay systems

Sampling frequencies for most parameters² for Chichester, Grahamstown, Lemon Tree Passage and Nelson Bay / Anna Bay systems are at least equal to the frequency recommended in Table 10.7 of the ADWG (2004, p.10-16). The last columns of Table 2, 10 and 12 indicates characteristics that are recommended in Table 10.7 for monitoring in raw and treated waters.

Where the recommended sampling frequency is “annually if at all”, Hunter Water has adopted (as a minimum) a default frequency of once every 5 years.

² The exceptions are minor, e.g. ADWG Table 10.7 suggests weekly monitoring for temperature, however, monthly monitoring is undertaken, as operational experience shows that monthly monitoring is adequate to track change in temperature in the distribution system over time.

TABLE 10 ROUTINE DRINKING WATER MONITORING PARAMETERS TREATED WATER – CHICHESTER, GRAHAMSTOWN, LEMON TREE PASSAGE AND NELSON BAY / ANNA BAY ZONES

Parameter	Frequency	No. of locations	Analysis by:	ADWG Table 10.7
pH	Daily	5	HWA Water Treatment	√
Turbidity	Daily	5	HWA Water Treatment	√
Hardness	Monthly	5	HWA	√
Total Dissolved Solids	Quarterly	5	HWA	√
Fluoride	Daily	5	HWA Water Treatment	√
Iron	Daily at Grahamstown and Weekly at Lemon Tree Passage, Anna Bay and Nelson Bay	6	HWA Water Treatment	√
Manganese			HWA Water Treatment	√
Aluminium	Weekly	5	HWA Water Treatment	√
Chlorine	Daily	5	HWA Water Treatment	√
Particle Count	On-Line	Grahamstown and Dungog	HWA Water Treatment	
Cryptosporidium	Analysis is routinely undertaken quarterly for treated surface waters. Note that treated water samples are taken for all sources at same frequency as for raw waters. Analysis is undertaken if Cryptosporidium or Giardia is detected in corresponding raw water.	Grahamstown and Dungog	HWA	
Giardia				
Heterotrophic Plate Count	Weekly	5	HWA	√
<i>E. coli</i>	Weekly	5	HWA	√
Total Coliforms	Weekly	5	HWA	√
Free Ammonia	Monthly	5	HWA	
Nitrites	Monthly	5	HWA	
Nitrates	Monthly	5	HWA	
Cyanide	Quarterly	5	ALS	
Sulphide	Quarterly	5	HWA	
Iodide	Quarterly	5	AWQC	
Antimony	Quarterly	5	HWA	
Aluminium	Quarterly	5	HWA	√
Arsenic	Quarterly	5	HWA	
Barium	Quarterly	5	HWA	
Beryllium	Quarterly	5	HWA	
Boron	Quarterly	5	ALS	
Cadmium	Quarterly	5	HWA	
Chloride	Quarterly	5	HWA	√
Chromium	Quarterly	5	HWA	
Copper	Quarterly	5	HWA	
Lead	Quarterly	5	HWA	
Molybdenum	Quarterly	5	HWA	
Mercury	Quarterly	5	HWA	
Nickel	Quarterly	5	HWA	
Selenium	Quarterly	5	HWA	
Silver	Quarterly	5	HWA	

Parameter	Frequency	No. of Locations	Analysis by:	ADWG Table 10.7
Sodium	Quarterly	5	HWA	√
Sulphate	Quarterly	5	HWA	√
Zinc	Quarterly	5	HWA	
Acrylamide	Quarterly	3	ARL	√
Carbon Tetrachloride	Quarterly	5	ARL	√
Epichlorohydrin	Once every five years	5	ARL	√

ALS = Australian Laboratory Services (Sydney)
AGAL = Australian Government Analytical Laboratories (Sydney)
ARL = Analytical Reference Laboratory (WA)
AWQC = Australian Water Quality Centre
HWA = Hunter Water Australia Laboratories
HWA Water Treatment = Hunter Water Australia Process and Operations i.e. analysis is carried out at Water Treatment Plants
(Hunter Water Australia is a fully owned subsidiary of Hunter Water Corporation)

7.5.2 Gresford Water Treatment Plant (WTP)

An operator attends Gresford Water Treatment plant three times a week. The plant is telemetered, with on-line monitoring and appropriate alarms set for pH, turbidity and chlorine.

Routine water quality monitoring for the Gresford WTP is shown below.

TABLE 11 Routine drinking water monitoring parameters for Gresford WTP treated water

Parameter	Frequency	No. of Locations	Analysis by:
<i>E.coli</i>	Weekly	1 (CWT)	HWA Laboratories
Total Coliforms	Weekly	1 (CWT)	HWA Laboratories
pH	3 times a week	1 (CWT)	HWA Water Treatment
Chlorine	3 times a week	1 (CWT)	HWA Water Treatment
Turbidity	3 times a week	1 (CWT)	HWA Water Treatment
Colour	3 times a week	1 (CWT)	HWA Water Treatment
Conductivity	3 times a week	1 (CWT)	HWA Water Treatment
Iron	3 times a week	1 (CWT)	HWA Water Treatment
Manganese	3 times a week	1 (CWT)	HWA Water Treatment
Aluminium	3 times a week	1 (CWT)	HWA Water Treatment

TABLE 12 ROUTINE ANALYSIS DISTRIBUTION SYSTEM – SAMPLE POINTS AT CUSTOMERS’ WATER SERVICES – CHICHESTER, GRAHAMSTOWN, LEMON TREE PASSAGE AND NELSON BAY / ANNA BAY ZONES

Parameter	Frequency	No. of locations	Analysis by:	ADWG Table 10.7
Total Coliforms	Fortnightly ³	66	HWA	√
<i>E. coli</i>	Fortnightly ³	66	HWA	√
Heterotrophic Plate Count	Fortnightly ³	66	HWA	√
Free Chlorine	Fortnightly ³	66	HWA	√
Iron	Fortnightly ³	66	HWA	√
Manganese	Fortnightly ³	66	HWA	√
Fluoride	Fortnightly ³ at 8 locations / Weekly at 6 locations	8 / 6	HWA	
Turbidity	Fortnightly ³	66	HWA	√
pH	Fortnightly ³	66	HWA	√
Conductivity	Fortnightly ³	66	HWA	
Temperature	Monthly	15	HWA	√
Dissolved Oxygen	Monthly	15	HWA	√
True Colour	Monthly	15	HWA	√
Aluminium Total	Fortnightly at 8 locations / Weekly at 6 locations	8 / 6	HWA	√
Aluminium Soluble		8 / 6	HWA	√
Lead	Monthly	15	HWA	√
Copper	Monthly	15	HWA	√
Zinc	Monthly	15	HWA	√
Trihalomethanes	Monthly	9	Labmark	√
Ammonia	Monthly	16	HWA	√
Sulphide	Monthly	16	HWA	√
Nitrates	Monthly	16	HWA	√
Nitrites	Monthly	16	HWA	√
Antimony	Quarterly	15	HWA	√
Cadmium	Quarterly	15	HWA	√
Nickel	Quarterly	15	HWA	√
Chromium	Quarterly	15	HWA	√
Asbestos	Annually	16	Adelaide Microscopy	√
Cyanide	Annually	16	ALS	√
Benzo-(a)-pyrene	Annually	5	SGS	√
Toluene	Once every five years	9	ARL	√
Xylene	Once every five years	9	ARL	√
Plasticisers	Once every five years	9	ARL	√
Di(2-ethylhexyl)phthalate				
Di(2-ethylhexyl)adipate				

ALS = Australian Laboratory Services (Sydney)

Labmark (Asquith)

Adelaide Microscopy

ARL = Analytical Reference Laboratory (WA)

SGS = SGS Laboratories Melbourne

HWA = Hunter Water Australia Laboratories

(Hunter Water Australia is a fully owned subsidiary of Hunter Water Corporation)

³ Note that fortnightly sampling is undertaken on a “week about” basis, i.e. weekly sampling is undertaken.

7.5.3 Gresford distribution system

Hunter Water undertakes the following routine verification monitoring within the distribution system at Gresford as shown in the following table.

TABLE 13 ROUTINE ANALYSIS DISTRIBUTION SYSTEM – SAMPLE POINTS AT CUSTOMERS’ WATER SERVICES – GRESFORD

Parameter	Frequency
Total Coliforms	Fortnightly
<i>E. coli</i>	Fortnightly
Free Chlorine	Fortnightly
pH	Fortnightly
Turbidity	Fortnightly
Total Dissolved Solids (TDS)	Six-monthly
Antimony	Six-monthly
Arsenic	Six-monthly
Barium	Six-monthly
Boron	Six-monthly
Cadmium	Six-monthly
Calcium	Six-monthly
Chloride	Six-monthly
Chromium	Six-monthly
Copper	Six-monthly
Iodine	Six-monthly
Iron	Six-monthly
Lead	Six-monthly
Magnesium	Six-monthly
Manganese	Six-monthly
Mercury	Six-monthly
Molybdenum	Six-monthly
Nickel	Six-monthly
Nitrate	Six-monthly
Nitrite	Six-monthly
Selenium	Six-monthly
Silver	Six-monthly
Sodium	Six-monthly
Sulfate	Six-monthly
Total Hardness as CaCO ₃	Six-monthly
Zinc	Six-monthly

7.6 Laboratory testing and reporting processes

7.6.1 Quality assurance

Independently accredited testing methods and a NATA accredited laboratory, operating with NATA accredited methods are used for all parameters for verification monitoring (with two exceptions⁴). Hunter Water ensures that testing methods used for verification monitoring have the required sensitivity and that samples are taken in a manner necessary to ensure no contamination or degradation of the samples.

Sampling and analysis for drinking water quality compliance is arranged by Hunter Water Australia Laboratories (HWAL). Sampling is undertaken in compliance with NATA accreditation to ensure a representative sample is taken. Analysis for some parameters is outsourced to other laboratories by HWAL. NATA accredited laboratories used for outsources analysis include Australian Laboratory Services (ALS), Australian Government Analytical Laboratories (AGAL), Labmark, Analytical Reference Laboratory (ARL) and the Australian Water Quality Centre (AWQC).

Analysis for operational purposes is undertaken by Hunter Water Australia Process and Operations (HWAPO) and is not NATA accredited. However, an appropriate system of quality assurance is used for this analysis

7.6.2 Data verification and record keeping

HWA Labs have QA systems in place for data verification and record keeping. All original records are kept for a minimum of five years. Checks are undertaken on transfer of data from one system to another. Verification by a senior officer is required for results which are outside of “normal” range. Laboratory data is stored on a Laboratory Information Management System (LIMS). This data is copied to Hunter Water’s data warehouse. Data may be extracted for reporting purposes and trend analysis, either directly from the LIMS, or from the data warehouse.

⁴ *Except for asbestos and radiological analysis. NATA accreditation for these parameters is not available in Australia. Analysis for these parameters is undertaken using quality-assured procedures, which have been reviewed and found to be satisfactory by Hunter Water.*

8 DEFINITIONS, ACRONYMS, AND ABBREVIATIONS

ADWG	National Health and Medical Research Council (NHMRC) and Natural Resource Management Ministerial Council (NRMMC) 2004 AUSTRALIAN DRINKING WATER GUIDELINES
AESTHETIC GUIDELINE VALUES	AESTHETIC GUIDELINE VALUES are contained in the Australian Drinking Water Guidelines and mean the concentration or measure of a water quality characteristic (a physical property of the water or a chemical) that is associated with good quality water.
CWT	CLEAR WATER TANK
DRINKING WATER	DRINKING WATER means water that, (following water treatment to the standard for use as drinking water specified in the Australian Drinking Water Guidelines), is supplied via the Water Supply System primarily for human consumption but which has other personal, domestic or household uses such as bathing and showering.
FRAMEWORK	FRAMEWORK FOR MANAGEMENT OF DRINKING WATER QUALITY
HEALTH-RELATED GUIDELINE VALUES	HEALTH-RELATED GUIDELINE VALUES are contained in the Australian Drinking Water Guidelines and mean the concentration or measure of a water quality characteristic, based on present knowledge that does not result in any significant risk to the health of the consumer over a lifetime of consumption.
HWA	HUNTER WATER AUSTRALIA HWA is a fully owned subsidiary of HWC. HWA operates all HWC's water treatment plants, and undertakes Laboratory services for HWC.
HWC	HUNTER WATER CORPORATION
IPART	INDEPENDENT PRICING AND REGULATORY TRIBUNAL
MOU	MEMORANDUM OF UNDERSTANDING Memorandum of Understanding between HUNTER WATER and NSW Health
NATA	NATIONAL ASSOCIATION OF TESTING AUTHORITIES
NHMRC	NATIONAL HEALTH AND MEDICAL RESEARCH COUNCIL
NRMMC	NATURAL RESOURCE MANAGEMENT MINISTERIAL COUNCIL
NSW HEALTH	NSW HEALTH means Hunter New England Area Health Service and the New South Wales Department of Health.
OPERATING LICENCE	HUNTER WATER CORPORATION OPERATING LICENCE is granted by the State Government and administered by the Independent Pricing and Regulatory Tribunal (IPART). The operating licence is the major customer protection instrument and prescribes standards of service that must be met in relation to water quality, continuity, pressure and wastewater transportation.
RWT	RAW WATER TANK
SCADA	SUPERVISORY CONTROL AND DATA ACQUISITION
WTP	WATER TREATMENT PLANT

9 REFERENCES

Rizak S and Hrudey SE, 2007 *Strategic Water Quality Monitoring for Drinking Water Safety*. Cooperative Research Centre for Water Quality and Treatment Research Report No 37.

http://www.wqra.com.au/publications/report37_strategic_water_monitoring.pdf

2004 Australian Drinking Water Guidelines

National Health and Medical Research Council (NHMRC) and Natural Resource Management Ministerial Council (NRMMC)

<http://www.nhmrc.gov.au/publications/synopses/eh19syn.htm>

Hunter Water Corporation Operating Licence 2007-2012

http://www.hunterwater.com.au/files/HWC_Operating_Licence_190607.pdf

10 ATTACHMENTS

Attachment 1: Plan showing water quality sample points and water supply zones for Newcastle, Lake Macquarie, Maitland, Cessnock, Port Stephens and Dungog areas.