



MAX DEFLECTION AT JOINTS		
PIPE DN	DEFLECTION	OFFSET FOR 5.5m PIPE
100 - 300	5"	480
375	4"	380
450 - 750	3"	290

NOTES:
1 FOR PIPE SUPPORT AND TRENCH FILL SEE DWG. WCP-202.

REV. N°	A	DUAL WATER SERVICES - 25mm TAPPING & MATERIAL	J.R.G.	01-07-02
		REVISION	APPROVED	DATE
APPROVED <i>J.R. Gibson</i>		APPROVED		
MANAGER CEC CONSULTING ENGINEERS		MANAGER PLANNING AND DEVELOPMENT		

HUNTER WATER CORPORATION
ABN 46 228 513 446

STANDARD CONSTRUCTION PRACTICE
WATER STANDARD

MAINLAYING - DICL MAINS
TYP. INSTALLATION OF PIPES & FITTINGS
FOR DN 100 TO 750 MAINS

CAD FILE NAME: WCP-200

HWCS
WCP-200

ISSUED: 1997

A3