



NOTES:

1. ALL DIMENSIONS IN MILLIMETRES UNLESS OTHERWISE NOTED.
2. PROPERTY OWNER TO PROVIDE POWER SUPPLY AND ELECTRICAL WORKS UP TO AND INCLUDING THE IP56 RATED ISOLATION SWITCH. ELECTRICAL CONTROLS AND ALARMS TO BE INSTALLED BY HUNTER WATER. USE APPROVED PRODUCTS ONLY.
3. PROVIDE AND CONNECT ALL SANITARY DRAINAGE TO AS3500.
4. GALVANISED STEEL CABLE COVERS TO BE PLACED OVER ELECTRICAL CONDUITS BETWEEN CONTROL/ALARM PANEL AND WHERE THE CONTROL CABLE ENTERS THE GROUND.
5. TANK TO COMPLY WITH WSA-PS-402.
6. SCREW CAP TO BE INSTALLED BY PROPERTY OWNER'S PLUMBER WITH "DO NOT ROD/JET" LABEL ON CAP.
7. TANK TO BE MAXIMUM 3M FROM COUNCIL SET BACK.
8. HWC PIPEWORK TO BE CONSTRUCTED WITH COMPACTED STABILISED SAND SURROUND.
9. MOAT TO BE 10mm SINGLE SIZED AGGREGATE.
10. BOUNDARY ONLY APPLIES TO ALL NEW SINGLE DWELLING RESIDENTIAL PREMISES SERVICED BY PRESSURE SEWER.
11. TANK COVER TO BE LOCKABLE WITH OPS 3 LOCK

NOT TO SCALE

WITH ACKNOWLEDGEMENT TO 	PRESSURE SEWERAGE CODE OF AUSTRALIA ON-PROPERTY LAYOUT TYPICAL ARRANGEMENT AND SANITARY DRAINAGE DETAILS	NOT TO SCALE PSS-1101-V ISSUED 2017 VERSION 2.0	© COPYRIGHT
---------------------------------	---	---	-------------