



**NOTES:**

1. PROVIDE NOM. 50 x 50 SQUARE SS316 PLATE PACKERS TO A THICKNESS OF 25mm BETWEEN U/SIDE OF SUPPORT FRAME FLANGE & TOP OF SLAB. LOCATE PACKER SETS LOCAL TO EACH CORNER & MID-WAY ALONG EACH SIDE.
2. FLEXIBLE EPOXY SEALANT TO BE MIXED IN ACCORDANCE WITH MANUFACTURER'S GUIDELINES TO A FLOWABLE CONSISTENCY FOR POURING. PREPARE CONTACT SURFACES AND PLACE SEALANT IN ACCORDANCE WITH MANUFACTURERS RECOMMENDATIONS.
3. FOUR TABS TO BE FITTED TO GAS TIGHT COVER FRAME ASSEMBLY HORIZONTALLY BOLTED TO WALL TO SUPPORT THE ENTIRE HINGED COVERS. PACKING NEEDED BEHIND EACH TAB.

1	SAFETY SCREENS REMOVED. EXPOXY SEALANT AT DETAIL. ADDITION OF NOTE 3	S.H.	1/06/2016
REV. N°	REVISION	APPROV	DATE
APPROVED		APPROVED	
© COPYRIGHT HUNTER WATER CORPORATION		MANAGER ASSET MANAGEMENT	



STANDARD CONSTRUCTION PRACTICE  
**SEWERAGE STANDARD**  
 SEWAGE PUMPING STATIONS  
 GAS-TIGHT WET-WELL COVERS  
 GENERAL ARRANGEMENT (ELEVATION)

CAD FILE NAME: SCP-811

**SCP-811**

ISSUED: 2016

A3