



2 / $\phi 16$ HOLES -SUPPLY 2/M12 CHEMICAL ANCHOR ADHESIVE CARTRIDGE
 -2/M12 x 140 LG THREADED ROD (CHISEL ONE END)
 C/W NUT & WASHER, ALL 316 SS

50 x 6 FL (316 SS)

$\phi 12$ HOLES, SHOP FIT
 2/M10 x 30 LG HEX
 BOLTS C/W NUT &
 WASHER, ALL 316 SS

INDUCT VENT PIPE CLIP

NOTES

- INDUCT VENT PIPE CLIP SHALL BE STAINLESS STEEL 316

VIEW

1	TITLE BLOCK AMENDED	S.H.	01-06-2016
REV. N ^o	REVISION	APPROVED	DATE
© COPYRIGHT HUNTER WATER CORPORATION LIMITED.		APPROVED MANAGER ASSET MANAGEMENT	



STANDARD CONSTRUCTION PRACTICE
SEWERAGE STANDARD

SEWAGE PUMPING STATIONS
 INDUCT VENT PIPE CLIP

CAD FILE NAME:	SCP-905
HWCS	
SCP-905	
ISSUED:	2016
	A3