



SECTIONAL ELEVATION
SCALE 1: 50

No.	DESCRIPTION	WSA P.S.
1	SC/SP DICL PIPE (LENGTH TO SUIT)	200
2	FL/SP DICL PIPE C/W FITTED PUDDLE FLANGE	200
3	316 SS RESILIENT SEATED KNIFEGATE VALVE C/W EXTENSION SPINDLE	260, 262
4	316 SS DROPTUBE - REFER TO SCP-902	
5	FL/SP DICL PIPE C/W FITTED PUDDLE FLANGE	200
6	SC/SP DICL PIPE (LENGTH TO SUIT)	200
7	GIBAULT COUPLING (<=DN300) OR DISMANTLING JOINT (GREATER THAN DN300)	270
8	PN35 FL/SP DICL PIPE	200
9	FL/FL NON-RETURN VALVE C/W COUNTERWEIGHT ARM	264
10	FL/FL STOP VALVE C/W EXTENSION SPINDLE	260, 262
11	45° SC/SC DI BEND C/W THRUST BLOCK	201
12	SP/SP DICL PIPE (LENGTH TO SUIT)	200
13	SC/SC-SC DI ANGLE BRANCH C/W THRUST BLOCK	201
14	FL/SP DICL PIPE C/W FITTED PUDDLE FLANGE	200
15	FL/FL STOP VALVE C/W EXTENSION SPINDLE AND SURFACE BOX INSTALLATION	260, 262
16	FL/SP DICL PIPE	200
17	FL/FL-FL DI EQUAL TEE C/W THRUST BLOCK	201
18	FL/SC DI CONNECTOR	201
19	FL/SP DICL PIPE	200
20	90° FL/FL DI VERTICAL BEND	201
21	FL/FL DICL PIPE	200
22	MALE "CAMLOCK" FLANGED COUPLER C/W DUST CAP	
23	FL/FL DICL PIPE	200
24	PVC PRESSURE PIPE C/W FLAP VALVE TO SUIT	211
25	LEVEL INSTRUMENT	
26	WELL FLOAT	
27	OVERFLOW	

NOTES:
1. FOR BLOCKOUT REPAIR DETAILS REFER TO SCP-901.

0	CONSTRUCTION ISSUE	S.H.	1/06/2016
REV. N°	REVISION	APPROV	DATE
APPROVED		APPROVED	
© COPYRIGHT HUNTER WATER CORPORATION		MANAGER ASSET MANAGEMENT	



STANDARD CONSTRUCTION PRACTICE
SEWERAGE STANDARD
SEWAGE PUMPING STATION
TYPICAL PIPEWORK ARRANGEMENT AND DETAIL SECTION

CAD FILE NAME: SCP-913
SCP-913
ISSUED: 2016