



BRANXTON WASTEWATER TREATMENT WORKS - FEBRUARY MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 1680
 Date Obtained: 4 March 2014
 Date Published: 17 March 2014

Licensee Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 1 Site Code 5SL0500		Site Description - Outlet from Farmers Reuse Storage										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 February 2014 to 28 February 2014								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Chlorine (total residual)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Faecal Coliforms	colony forming units per 100 mL	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrate+nitrite (oxidised nitrogen)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
pH	pH	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	6.50 - 8.50	- - -	Yes
Phosphorus (total)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Kjeldahl Nitrogen	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A

* No samples were collected as no discharge occurred during the month

EPA Id. No. 11 Site Code 5BL0500		Site Description - Discharge to Black Creek from Reuse Water Storage										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting [^]	Monthly Summary 1 February 2014 to 28 February 2014								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Chlorine (total residual)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A

[^] No samples were collected as no discharge occurred during the month

EPA Id. No. 12 Site Code 5SK0535		Site Description - Reuse Water Pump Station										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 February 2014 to 28 February 2014								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Weekly	4	<2	2	<2	2	N/A	N/A	N/A	N/A	N/A
Faecal Coliforms	colony forming units per 100 mL	Weekly	4	0	0	0	0	N/A	N/A	N/A	N/A	N/A
Nitrate+nitrite (oxidised nitrogen)	milligrams per litre	Monthly	1	4.5	4.5	4.5	4.5	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Monthly	1	0.06	0.06	0.06	0.06	N/A	N/A	N/A	N/A	N/A
pH	pH	Weekly	4	7.46	7.54	7.52	7.66	N/A	N/A	6.50 - 8.50	7.46 - 7.66	Yes
Phosphorus (total)	milligrams per litre	Monthly	1	0.42	0.42	0.42	0.42	N/A	N/A	N/A	N/A	N/A
Total Kjeldahl Nitrogen	milligrams per litre	Monthly	1	1.4	1.4	1.4	1.4	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Weekly	4	<1	<1	<1	<1	N/A	N/A	N/A	N/A	N/A

EPA Id. No. 13 Site Code 5OV0500		Site Description - Outlet from Wet Weather Storage Pond.										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting [#]	Monthly Summary 1 February 2014 to 28 February 2014								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Faecal Coliforms	colony forming units per 100 mL	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrate+nitrite (oxidised nitrogen)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
pH	pH	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Phosphorus (total)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Kjeldahl Nitrogen	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A

[#] No samples were collected as no overflow occurred during the month