



**BRANXTON WASTEWATER TREATMENT WORKS - MARCH MONTHLY POLLUTION MONITORING SUMMARY**

Environment Protection Licence No. 1680  
 Date Obtained: 5 April 2017  
 Date Published: 20 April 2017

Licensee  
 Hunter Water Corporation  
 36 Honeysuckle Drive  
 NEWCASTLE WEST NSW 2302

**QUALITY MONITORING**

EPA Id. No. 1 Site Code 5SL0500		Site Description - Outlet from Farmers Reuse Storage										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting *	Monthly Summary 1 March 2017 to 31 March 2017								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Chlorine (total residual)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Faecal Coliforms	colony forming units per 100 mL	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrate+nitrite (oxidised nitrogen)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
pH	pH	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	6.50 - 8.50	- - -	N/A
Phosphorus (total)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Kjeldahl Nitrogen	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A

\* No samples were collected as no discharge occurred during the month

EPA Id. No. 11 Site Code 5BL0500		Site Description - Discharge to Black Creek from Reuse Water Storage										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting***	Monthly Summary 1 March 2017 to 31 March 2017								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Chlorine (total residual)	milligrams per litre	First 24hrs then weekly	2	<0.1	<0.1	<0.1	<0.1	N/A	N/A	N/A	N/A	N/A

\*\*\* Discharge occurred 28 Feb 2017 at approximately 11pm. Sample was collected on 1 Mar 2017 within 24 hours of discharge event as required by EPL 1680 and will therefore be included in the report for March.

EPA Id. No. 12 Site Code 5SK0535		Site Description - Reuse Water Pump Station										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 March 2017 to 31 March 2017								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Weekly	5	<2	<2	<2	<2	N/A	N/A	N/A	N/A	N/A
Faecal Coliforms	colony forming units per 100 mL	Weekly	5	0	0	0	0	N/A	N/A	N/A	N/A	N/A
Nitrate+nitrite (oxidised nitrogen)	milligrams per litre	Monthly	1	4.5	4.5	4.5	4.5	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Monthly	1	0.09	0.09	0.09	0.09	N/A	N/A	N/A	N/A	N/A
pH	pH	Weekly	5	7.07	7.26	7.26	7.43	N/A	N/A	6.50 - 8.50	7.07 - 7.43	Yes
Phosphorus (total)	milligrams per litre	Monthly	1	0.10	0.10	0.10	0.10	N/A	N/A	N/A	N/A	N/A
Total Kjeldahl Nitrogen	milligrams per litre	Monthly	1	0.6	0.6	0.6	0.6	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Weekly	5	<1	<1	<1	<1	N/A	N/A	N/A	N/A	N/A

EPA Id. No. 13 Site Code 5OV0500		Site Description - Outlet from Wet Weather Storage Pond.										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting **	Monthly Summary 1 March 2017 to 31 March 2017								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Faecal Coliforms	colony forming units per 100 mL	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrate+nitrite (oxidised nitrogen)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
pH	pH	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Phosphorus (total)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Kjeldahl Nitrogen	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A

\*\* No samples were collected as no discharge occurred during the month