



CLARENCE TOWN WASTEWATER TREATMENT WORKS - FEBRUARY MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 13250
 Date Obtained: 10 March 2017
 Date Published: 16 March 2017

Licensee Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 1 Site Code 5CT0001		Site Description - Discharge to utilisation area										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 February 2017 to 28 February 2017								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Aluminium	milligrams per litre	Yearly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
BOD	milligrams per litre	Weekly	4	11	37	38	60	N/A	N/A	N/A	N/A	N/A
Cadmium	milligrams per litre	Yearly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Chloride	milligrams per litre	Monthly	1	54	54	54	54	N/A	N/A	N/A	N/A	N/A
Chlorophyll a	milligrams per litre	Weekly	4	0.0294	0.161	0.196	0.223	N/A	N/A	N/A	N/A	N/A
Chromium	milligrams per litre	Yearly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Conductivity	microsiemens per centimetre	Quarterly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Copper	milligrams per litre	Yearly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Faecal Coliforms	colony forming units per 100 mL	Monthly	1	64	64	64	64	N/A	N/A	N/A	N/A	N/A
Iron	milligrams per litre	Yearly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Lead	milligrams per litre	Yearly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Magnesium	milligrams per litre	Yearly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Manganese	milligrams per litre	Yearly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Mercury	milligrams per litre	Yearly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrate	milligrams per litre	Monthly	1	<0.05	<0.05	<0.05	<0.05	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Monthly	1	4.7	4.7	4.7	4.7	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Monthly	1	<2	<2	<2	<2	N/A	N/A	N/A	N/A	N/A
pH	pH	Weekly	4	7.04	7.74	7.14	9.64	N/A	N/A	N/A	N/A	N/A
Potassium	milligrams per litre	Monthly	1	18.4	18.4	18.4	18.4	N/A	N/A	N/A	N/A	N/A
Total Nitrogen	milligrams per litre	Monthly	1	9.6	9.6	9.6	9.6	N/A	N/A	N/A	N/A	N/A
Total Phosphorous	milligrams per litre	Monthly	1	4.7	4.7	4.7	4.7	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Weekly	4	22	30	29	42	N/A	N/A	N/A	N/A	N/A
Zinc	milligrams per litre	Yearly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A

EPA Id. No. 2 Site Code 5OV3100		Site Description - Overflow spillway										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting*	Monthly Summary 1 February 2017 to 28 February 2017								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
BOD	milligrams per litre	Special Frequency 1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Chlorophyll a	milligrams per litre	Special Frequency 1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrate	milligrams per litre	Special Frequency 1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Special Frequency 1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Special Frequency 1	-	-	-	-	-	N/A	N/A	10	-	N/A
pH	pH	Special Frequency 1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Nitrogen	milligrams per litre	Special Frequency 1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Phosphorous	milligrams per litre	Special Frequency 1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Special Frequency 1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A

* No samples were collected as no overflow occurred during the month

EPA Id. No. 5 Site Code 5CT0035		Site Description - Pumped discharge to Wallaroo Creek										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting**	Monthly Summary 1 February 2017 to 28 February 2017								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
BOD	milligrams per litre	Special Frequency 1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Chlorophyll a	milligrams per litre	Special Frequency 1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrate	milligrams per litre	Special Frequency 1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Special Frequency 1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Special Frequency 1	-	-	-	-	-	N/A	N/A	10	-	N/A
pH	pH	Special Frequency 1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Nitrogen	milligrams per litre	Special Frequency 1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Phosphorous	milligrams per litre	Special Frequency 1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Special Frequency 1	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A

** No samples were collected as no discharge occurred during the month