



DORA CREEK WASTEWATER TREATMENT WORKS - MARCH MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 1771
 Date Obtained: 8 April 2013
 Date Published: 12 April 2013

Licensee
 Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 15 Site Code 5OV0800		Site Description - Dora Creek WWTW overflow										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting #	Monthly Summary 1 March 2013 to 31 March 2013								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Daily during any discharge	2	<2	5	5	7	N/A	N/A	N/A	N/A	N/A
pH	pH	Daily during any discharge	2	6.97	7.03	7.03	7.08	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Daily during any discharge	2	4	16	16	27	N/A	N/A	N/A	N/A	N/A