



DUNGOG WATER TREATMENT PLANT - APRIL MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 3232
 Date Obtained: 26 April 2012
 Date Published: 28 June 2012

Licensee Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 1 Site Code		Site Description - Stormwater culvert at boundary of plant on the north side of Wade Street									
Pollutant	Unit of Measurement	Sampling Frequency	Monthly Summary 1 April 2012 to 30 April 2012								
			Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Total Suspended Solids	milligrams per litre	Monthly	14	14	14	14	N/A	N/A	50	14	Yes
Aluminium	milligrams per litre	Monthly	0.10	0.10	0.10	0.10	N/A	N/A	N/A	N/A	N/A
Iron	milligrams per litre	Monthly	0.26	0.26	0.26	0.26	N/A	N/A	N/A	N/A	N/A
Manganese	milligrams per litre	Monthly	0.073	0.073	0.073	0.073	N/A	N/A	N/A	N/A	N/A
pH	pH	Monthly	7.23	7.23	7.23	7.23	N/A	N/A	N/A	N/A	N/A