

DUNGOG WATER TREATMENT PLANT - MAY MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 3232
 Date Obtained: 31 May 2012
 Date Published: 28 June 2012

Licensee Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302



QUALITY MONITORING

EPA Id. No. 1 Site Code	Site Description - Stormwater culvert at boundary of plant on the north side of Wade Street											
Pollutant	Unit of Measurement	Sampling Frequency	Monthly Summary 1 May 2012 to 31 May 2012									Within Limits
			Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual		
Total Suspended Solids	milligrams per litre	Monthly	14	14	14	14	N/A	N/A	50	14	Yes	
Aluminium	milligrams per litre	Monthly	0.03	0.03	0.03	0.03	N/A	N/A	N/A	N/A	N/A	
Iron	milligrams per litre	Monthly	1.78	1.78	1.78	1.78	N/A	N/A	N/A	N/A	N/A	
Manganese	milligrams per litre	Monthly	0.617	0.617	0.617	0.617	N/A	N/A	N/A	N/A	N/A	
pH	pH	Monthly	7.66	7.66	7.66	7.66	N/A	N/A	N/A	N/A	N/A	