



## DUNGOG WATER TREATMENT PLANT - JUNE MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 3232

Date Obtained: 26 June 2012

Date Published: 16 July 2012

**Licensee**

Hunter Water Corporation  
36 Honeysuckle Drive  
NEWCASTLE WEST NSW 2302

### QUALITY MONITORING

EPA Id. No. 1 Site Code	Site Description - Stormwater culvert at boundary of plant on the north side of Wade Street											
Pollutant	Unit of Measurement	Sampling Frequency	Monthly Summary 1 June 2012 to 30 June 2012									Within Limits
			Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual		
Total Suspended Solids	milligrams per litre	Monthly	2	2	2	2	N/A	N/A	50	2	Yes	
Aluminium	milligrams per litre	Monthly	0.13	0.13	0.13	0.13	N/A	N/A	N/A	N/A	N/A	
Iron	milligrams per litre	Monthly	1.15	1.15	1.15	1.15	N/A	N/A	N/A	N/A	N/A	
Manganese	milligrams per litre	Monthly	0.29	0.29	0.29	0.29	N/A	N/A	N/A	N/A	N/A	
pH	pH	Monthly	7.46	7.46	7.46	7.46	N/A	N/A	N/A	N/A	N/A	