



## DUNGOG WATER TREATMENT PLANT - MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 3232

Date Obtained: 16 August 2012

Date Published: 28 August 2012

**Licensee**

Hunter Water Corporation  
36 Honeysuckle Drive  
NEWCASTLE WEST NSW 2302

### QUALITY MONITORING

EPA Id. No. 1 Site Code 1610111		Site Description - Stormwater culvert at boundary of plant on the north side of Wade Street									
Pollutant	Unit of Measurement	Sampling Frequency	Monthly Summary 1 August 2012 to 31 August 2012								
			Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Total Suspended Solids	milligrams per litre	Monthly	2	2	2	2	N/A	N/A	50	2	Yes
Aluminium	milligrams per litre	Monthly	0.32	0.32	0.32	0.32	N/A	N/A	N/A	N/A	N/A
Iron	milligrams per litre	Monthly	2.13	2.13	2.13	2.13	N/A	N/A	N/A	N/A	N/A
Manganese	milligrams per litre	Monthly	0.98	0.98	0.98	0.98	N/A	N/A	N/A	N/A	N/A
pH	pH	Monthly	7.11	7.11	7.11	7.11	N/A	N/A	N/A	N/A	N/A