



**DUNGOG WATER TREATMENT PLANT - MAY 2013 MONTHLY POLLUTION MONITORING SUMMARY**

Environment Protection Licence No. 3232  
 Date Obtained: 20 May 2013  
 Date Published: 23 May 2013

Licensee  
 Hunter Water Corporation  
 36 Honeysuckle Drive  
 NEWCASTLE WEST NSW 2302

**QUALITY MONITORING**

EPA Id. No. 1 Site Code 1610111		Site Description - Stormwater culvert at boundary of plant on the north side of Wade Street										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 May 2013 to 31 May 2013								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Total Suspended Solids	milligrams per litre	Monthly	1	<1	<1	<1	<1	N/A	N/A	50	<1	Yes
Aluminium	milligrams per litre	Monthly	1	0.23	0.23	0.23	0.23	N/A	N/A	N/A	N/A	N/A
Iron	milligrams per litre	Monthly	1	0.63	0.63	0.63	0.63	N/A	N/A	N/A	N/A	N/A
Manganese	milligrams per litre	Monthly	1	0.40	0.40	0.40	0.40	N/A	N/A	N/A	N/A	N/A
pH	pH	Monthly	1	7.10	7.10	7.10	7.10	N/A	N/A	N/A	N/A	N/A