



DUNGOG WATER TREATMENT PLANT - NOVEMBER MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 3232
 Date Obtained: 14 November 2013
 Date Published: 26 November 2013

Licensee Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 1 Site Code 1610111		Site Description - Stormwater culvert at boundary of plant on the north side of Wade Street										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 November 2013 to 30 November 2013								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Total Suspended Solids	milligrams per litre	Monthly	1	84	84	84	84	N/A	N/A	50	84	No
Aluminium	milligrams per litre	Monthly	1	4.20	4.20	4.20	4.20	N/A	N/A	N/A	N/A	N/A
Iron	milligrams per litre	Monthly	1	3.90	3.90	3.90	3.90	N/A	N/A	N/A	N/A	N/A
Manganese	milligrams per litre	Monthly	1	1.44	1.44	1.44	1.44	N/A	N/A	N/A	N/A	N/A
pH	pH	Monthly	1	6.78	6.78	6.78	6.78	N/A	N/A	N/A	N/A	N/A