



**DUNGOG WATER TREATMENT PLANT - JULY MONTHLY POLLUTION MONITORING SUMMARY**

Environment Protection Licence No. 3232  
 Date Obtained: 23 July 2014  
 Date Published: 29 July 2014

**Licensee** Hunter Water Corporation  
 36 Honeysuckle Drive  
 NEWCASTLE WEST NSW 2302

**QUALITY MONITORING**

EPA Id. No. 1 Site Code 1610111		Site Description - Stormwater culvert at boundary of plant on the north side of Wade Street											
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 July 2014 to 31 July 2014									Within Limits
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual		
Total Suspended Solids	milligrams per litre	Monthly	1	3	3	3	3	N/A	N/A	50	3	Yes	
Aluminium	milligrams per litre	Monthly	1	0.20	0.20	0.20	0.20	N/A	N/A	N/A	N/A	N/A	
Iron	milligrams per litre	Monthly	1	2.61	2.61	2.61	2.61	N/A	N/A	N/A	N/A	N/A	
Manganese	milligrams per litre	Monthly	1	1.21	1.21	1.21	1.21	N/A	N/A	N/A	N/A	N/A	
pH	pH	Monthly	1	6.98	6.98	6.98	6.98	N/A	N/A	N/A	N/A	N/A	