



DUNGOG WATER TREATMENT PLANT - MARCH MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 2863
 Date Obtained: 17 March 2016
 Date Published: 6 April 2016

Licensee Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 1 Site Code 1610111		Site Description - Stormwater culvert at boundary of plant on the north side of Wade Street											
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 March 2016 to 31 March 2016									Within Limits
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual		
Total Suspended Solids	milligrams per litre	Monthly	1	2	2	2	2	N/A	N/A	50	2	Yes	
Aluminium	milligrams per litre	Monthly	1	0.06	0.06	0.06	0.06	N/A	N/A	N/A	N/A	N/A	
Iron	milligrams per litre	Monthly	1	2.15	2.15	2.15	2.15	N/A	N/A	N/A	N/A	N/A	
Manganese	milligrams per litre	Monthly	1	1.31	1.31	1.31	1.31	N/A	N/A	N/A	N/A	N/A	
pH	pH	Monthly	1	6.90	6.90	6.90	6.90	N/A	N/A	N/A	N/A	N/A	