



## DUNOGG WATER TREATMENT PLANT - FEBRUARY MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 3232  
 Date Obtained: 12 May 2014  
 Date Published: 16 May 2014

Licensee  
 Hunter Water Corporation  
 36 Honeysuckle Drive  
 NEWCASTLE WEST NSW 2302

### QUALITY MONITORING

EPA Id. No. 1 Site Code 1610111		Site Description - Stormwater culvert at boundary of plant on the north side of Wade Street										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 February 2014 to 28 February 2014								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Total Suspended Solids	milligrams per litre	Monthly	1	21	21	21	21	N/A	N/A	50	21	Yes
Aluminium	milligrams per litre	Monthly	1	35.00	35.00	35.00	35.00	N/A	N/A	N/A	N/A	N/A
Iron	milligrams per litre	Monthly	1	9.32	9.32	9.32	9.32	N/A	N/A	N/A	N/A	N/A
Manganese	milligrams per litre	Monthly	1	4.130	4.130	4.130	4.130	N/A	N/A	N/A	N/A	N/A
pH	pH	Monthly	1	6.71	6.71	6.71	6.71	N/A	N/A	N/A	N/A	N/A

### CORRECTION LOG

EPA Id. No. 1 Site Code 1610111		Site Description - Stormwater culvert at boundary of plant on the north side of Wade Street						
Pollutant	Unit of Measurement	Original Data		Corrected Data		Date Corrected	Date Originally Published	Reason
		Minimum	Maximum	Minimum Actual	Maximum Actual			
Aluminium	milligrams per litre	35.00	35.00	0.035	0.035	15/05/2014	28/02/2014	Data Entry Error