



## DUNOGG WATER TREATMENT PLANT - APRIL MONTHLY POLLUTION MONITORING CORRECTION LOG

Environment Protection Licence No. 3232  
 Date Obtained: 26 April 2012  
 Date Published: 28 June 2012

**Licensee** Hunter Water Corporation  
 36 Honeysuckle Drive  
 NEWCASTLE WEST NSW 2302

### QUALITY MONITORING

EPA Id. No. 1 Site Code		Site Description - Stormwater culvert at boundary of plant on the north side of Wade Street									
Pollutant	Unit of Measurement	Sampling Frequency	Monthly Summary 1 April 2012 to 30 April 2012								
			Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Total Suspended Solids	milligrams per litre	Monthly	11	11	11	11	N/A	N/A	50	11	Yes
Aluminium	milligrams per litre	Monthly	0.20	0.20	0.20	0.20	N/A	N/A	N/A	N/A	N/A
Iron	milligrams per litre	Monthly	3.68	3.68	3.68	3.68	N/A	N/A	N/A	N/A	N/A
Manganese	milligrams per litre	Monthly	1.212	1.212	1.212	1.212	N/A	N/A	N/A	N/A	N/A
pH	pH	Monthly	7.23	7.23	7.23	7.23	N/A	N/A	N/A	N/A	N/A

### CORRECTION LOG

EPA Id. No. 1 Site Code		Site Description - Stormwater culvert at boundary of plant on the north side of Wade Street				
Pollutant	Unit of Measurement	Original Data	Corrected Data	Date Corrected	Date Originally Published	Reason
Total Suspended Solids	milligrams per litre	14	11	10 July 2012	28 June 2012	Data Entry Error
Iron	milligrams per litre	0.26	3.68	10 July 2012	28 June 2012	Data Entry Error
Manganese	milligrams per litre	0.073	1.21	10 July 2012	28 June 2012	Data Entry Error
Aluminium	milligrams per litre	0.10	0.20	10 July 2012	28 June 2012	Data Entry Error