



## EDGEWORTH WASTEWATER TREATMENT WORKS - JUNE MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 1771  
 Date Obtained: 29 July 2013  
 Date Published: 7 August 2013

**Licensee** Hunter Water Corporation  
 36 Honeysuckle Drive  
 NEWCASTLE WEST NSW 2302

### QUALITY MONITORING

| EPA Id. No. 7<br>Site Code 5SL0901 |                      | Site Description - Edgeworth WWTW Overflow |  |  |            |              |         |            |             |               |                |               |
|------------------------------------|----------------------|--|--|--|------------|--------------|---------|------------|-------------|---------------|----------------|---------------|
| Pollutant                          | Unit of Measurement  | Sampling Frequency                         | No. of times measured during the month for licence reporting | Monthly Summary<br>1 June 2013 to 30 June 2013 |            |              |         |            |             |               |                |               |
|                                    |                      |  |  | Minimum  | Mean Value | Median Value | Maximum | 3DGM Limit | 3DGM Actual | 100%ile Limit | 100%ile Actual | Within Limits |
| Biochemical Oxygen Demand          | milligrams per litre | Daily during any discharge                 | 2  | 3  | 3          | 3            | 3       | N/A        | N/A         | N/A           | N/A            | N/A           |
| pH                                 | pH                   | Daily during any discharge                 | 2  | 6.81   | 6.86       | 6.86         | 6.91    | N/A        | N/A         | N/A           | N/A            | N/A           |
| Total Suspended Solids             | milligrams per litre | Daily during any discharge                 | 2  | 6  | 7.5        | 7.5          | 9       | N/A        | N/A         | N/A           | N/A            | N/A           |