



EDGEWORTH WASTEWATER TREATMENT WORKS -ANNUAL POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 1771
 Date Obtained: 1 July 2015
 Date Published: 11 August 2015

Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 7 Site Code 5OV0900		Site Description - Edgeworth WWTW Overflow												
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the year for licence reporting	Annual Summary 1 July 2014 - 20 June 2015										
				Minimum	Maximum	50%ile Limit	50%ile Actual	90%ile Limit	90%ile Actual	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Daily during any discharge	20	<2	7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
pH	pH	Daily during any discharge	20	6.80	7.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Daily during any discharge	20	<1	19	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

EPA Id. No. 7 Site Code 5OV0900		Site Description - Edgeworth WWTW Overflow				
Pollutant	Unit of Measurement	Original Data	Corrected Data	Date Corrected	Date Originally Published	Reason
Biochemical Oxygen Demand	milligrams per litre	19	20	7/08/2015	21/07/2015	Data Entry Error.
pH	pH	19	20	7/08/2015	21/07/2015	Data Entry Error.
Total Suspended Solids	milligrams per litre	19	20	7/08/2015	21/07/2015	Data Entry Error.