



KURRI KURRI WASTEWATER TREATMENT WORKS - FEBRUARY MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 1767
 Date Obtained: 4 March 2014
 Date Published: 17 March 2014

Licensee Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 2 Site Code 5DE3005		Site Description - In UV Disinfection Channel following UV Treatment										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 February 2014 to 28 February 2014								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Weekly	4	<2	2	2	2	N/A	N/A	45	2	Yes
Faecal Coliforms	colony forming units per 100 mL	Monthly	1	<2	<2	<2	<2	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Monthly	1	2.70	2.70	2.70	2.70	N/A	N/A	N/A	N/A	N/A
Nitrogen (total)	milligrams per litre	Monthly	1	6.14	6.14	6.14	6.14	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Fortnightly	2	<5	<5	<5	<5	N/A	N/A	N/A	N/A	N/A
Phosphorus (total)	milligrams per litre	Weekly	4	0.07	0.08	0.07	0.10	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Weekly	4	<1	1	1	2	N/A	N/A	70	2	Yes
pH	pH	Weekly	4	7.03	7.11	7.12	7.15	N/A	N/A	6.50 - 8.50	7.03 - 7.15	Yes

EPA Id. No. 1 Site Code 5OV1000		Site Description - Pipe from No.3 Maturation Pond										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting #	Monthly Summary 1 February 2014 to 28 February 2014								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Daily during any Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Chlorophyll a	micrograms per litre	Daily during any Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Daily during any Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (total)	milligrams per litre	Daily during any Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Daily during any Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Phosphorus (total)	milligrams per litre	Daily during any Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Daily during any Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
pH	pH	Daily during any Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A

No samples were collected as no overflow occurred during the month