



KURRI KURRI WASTEWATER TREATMENT WORKS - OCTOBER MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 1767
 Date Obtained: 1 November 2017
 Date Published: 17 November 2017

Licensee Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 2 Site Code 5DE3005		Site Description - In UV Disinfection Channel following UV Treatment										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 October 2017 to 31 October 2017								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Weekly	4	<2	2	<2	3	N/A	N/A	N/A	N/A	N/A
Faecal Coliforms	colony forming units per 100 mL	Monthly	1	2	2	2	2	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Monthly	1	0.30	0.30	0.30	0.30	N/A	N/A	N/A	N/A	N/A
Nitrogen (total)	milligrams per litre	Monthly	1	5.3	5.3	5.3	5.3	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Fortnightly	2	<2	<2	<2	<2	N/A	N/A	N/A	N/A	N/A
pH	pH	Weekly	4	7.37	7.40	7.41	7.42	N/A	N/A	6.50 - 8.50	7.37 - 7.42	Yes
Phosphorus (total)	milligrams per litre	Weekly	4	0.029	0.046	0.045	0.065	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Weekly	4	<1	5	4	10	N/A	N/A	N/A	N/A	N/A

EPA Id. No. 1 Site Code 5OV1000		Site Description - Pipe from No.3 Maturation Pond										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting*	Monthly Summary 1 October 2017 to 31 October 2017								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Daily during any Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Chlorophyll a	micrograms per litre	Daily during any Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Daily during any Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (total)	milligrams per litre	Daily during any Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Daily during any Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
pH	pH	Daily during any Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Phosphorus (total)	milligrams per litre	Daily during any Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Daily during any Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A

*No samples were collected as no discharge occurred during the month