

SHORTLAND WASTEWATER TREATMENT WORKS - MAY MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 1683
Date Obtained: 3 June 2013
Date Published: 13 June 2013

Licensee

Hunter Water Corporation 36 Honeysuckle Drive NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA ld. No. 19 Site Code 5SL1810 Pollutant	Site Description -Shortland WWTW dechlorination building												
	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 May 2013 to 31 May 2013									
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits	
Biochemical Oxygen Demand	milligrams per litre	Weekly	5	<2	<2	<2	<2	N/A	N/A	80	<2	Yes	
Faecal Coliforms	colony forming units per 100 mL	Monthly	1	39	39	39	39	N/A	N/A	N/A	N/A	N/A	
Nitrate + Nitrite (oxidised nitrogen)	milligrams per litre	Monthly	1	10.10	10.10	10.10	10.10	N/A	N/A	N/A	N/A	N/A	
Nitrogen (ammonia)	milligrams per litre	Monthly	1	0.18	0.18	0.18	0.18	N/A	N/A	N/A	N/A	N/A	
Oil and Grease	milligrams per litre	Fortnightly	2	<5	<5	<5	<5	N/A	N/A	N/A	N/A	N/A	
рН	pH	Weekly	5	6.83	7.09	7.17	7.23	N/A	N/A	6.50 - 8.50	6.83 - 7.23	Yes	
Phosphorus (total)	milligrams per litre	Monthly	1	0.73	0.73	0.73	0.73	N/A	N/A	N/A	N/A	N/A	
Total Suspended Solids	milligrams per litre	Weekly	5	<1	2	<1	3	N/A	N/A	100	3	Yes	

EPA Id. No. 18 Site Code 5OV1800	Site Description -Shortland WWTW overflow											
	No. of times Monthly Summary measured during the 1 May 2013 to 31 May 2013											
Pollutant	Unit of Measurement	Sampling Frequency	month for licence reporting	Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Daily during any discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Daily during any discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
рН	pН	Daily during any discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Daily during any discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A