



SHORTLAND WASTEWATER TREATMENT WORKS - APRIL MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 1683
 Date Obtained: 30 April 2013
 Date Published: 13 May 2013

Licensee
 Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 19 Site Code 5SL1810		Site Description -Shortland WWTW dechlorination building										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 April 2013 to 30 April 2013								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Weekly	4	<2	<2	<2	<2	N/A	N/A	80	<2	Yes
Faecal Coliforms	colony forming units per 100 mL	Monthly	1	3	3	3	3	N/A	N/A	N/A	N/A	N/A
Nitrate + Nitrite (oxidised nitrogen)	milligrams per litre	Monthly	1	10.30	10.30	10.30	10.30	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Monthly	1	0.28	0.28	0.28	0.28	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Fortnightly	2	<5	<5	<5	<5	N/A	N/A	N/A	N/A	N/A
pH	pH	Weekly	4	6.99	7.11	7.08	7.3	N/A	N/A	6.50 - 8.50	6.99 - 7.30	Yes
Phosphorus (total)	milligrams per litre	Monthly	1	4.20	4.20	4.20	4.20	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Weekly	4	<1	2	2	4	N/A	N/A	100	4	Yes

EPA Id. No. 18 Site Code 5OV1800		Site Description -Shortland WWTW overflow										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 April 2013 to 30 April 2013								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Daily during any discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Daily during any discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
pH	pH	Daily during any discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Daily during any discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A