



SHORTLAND WASTEWATER TREATMENT WORKS - MARCH MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 1683
 Date Obtained: 7 April 2015
 Date Published: 16 April 2015

Licensee
 Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 20 Site Code 5SL1810		Site Description -Shortland WWTW dechlorination building										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 March 2015 to 31 March 2015								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Special Frequency 1	4	<2	2	<2	3	N/A	N/A	80	3	Yes
Faecal Coliforms	colony forming units per 100 mL	Special Frequency 1	4	<2	2	<2	2	N/A	N/A	N/A	N/A	N/A
Nitrate + Nitrite (oxidised nitrogen)	milligrams per litre	Special Frequency 1	4	<0.05	5.46	6.90	8.00	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Special Frequency 1	4	0.15	0.36	0.37	0.54	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Special Frequency 1	4	<5	<5	<5	<5	N/A	N/A	N/A	N/A	N/A
pH	pH	Special Frequency 1	4	6.80	6.93	6.90	7.10	N/A	N/A	6.50 - 8.50	6.80 - 7.10	Yes
Phosphorus (total)	milligrams per litre	Special Frequency 1	4	0.90	2.90	2.90	4.90	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Special Frequency 1	4	1	3	3	4	N/A	N/A	100	4	Yes

EPA Id. No. 18 Site Code 5OV1800		Site Description -Shortland WWTW overflow										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 March 2015 to 31 March 2015								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Daily during any discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Daily during any discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
pH	pH	Daily during any discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Daily during any discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A