SHORTLAND WASTEWATER TREATMENT WORKS - ANNUAL MONITORING SUMMARY

Environment Protection Licence No. 1683
Date Obtained: 7 July 2014
Date Published: 21 July 2014

Licensee Hunter Water Corporation
36 Honeysuckle Drive
NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 19 Site Code 5SL1810	Site Description -Shortland WWTW dechlorination building															
				Annual Summary 1 July 2012 to 30 June 2013												
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the year for licence reporting	Minimum	Maximum	50%ile Limit	50%ile Actual	90%ile Limit	90%ile Actual	3DGM Limit	3DGM Number of measurements	3DGM Minimum	3DGM Maximum	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Weekly	52	<2	8	25	<2	60	2	N/A	N/A	N/A	N/A	80	8	Yes
Faecal Coliforms	colony forming units per 100 mL	Monthly	16	0	160	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Nitrate + Nitrite (oxidised nitrogen)	milligrams per litre	Monthly	16	3.10	11.50	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Monthly	16	<0.05	1.90	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Fortnightly	29	<5	<5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
pH	pH	Weekly	52	6.64	7.66	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.5 - 8.5	6.64 - 7.66	Yes
Phosphorus (total)	milligrams per litre	Monthly	16	0.74	6.30	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Weekly	52	<1	20	40	4	80	11	N/A	N/A	N/A	N/A	100	20	Yes

EPA Id. No. 18 Site Code 5OV1800	Site Description -Shortland WWTW overflow															
				Annual Summary 1 July 2012 to 30 June 2013												
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the year for licence reporting	Minimum	Maximum	50%ile Limit	50%ile Actual	90%ile Limit	90%ile Actual	3DGM Limit	3DGM Number of measurements	3DGM Minimum	3DGM Maximum	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Daily during any discharge	3	2	10	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Daily during any discharge	3	1.60	2.20	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
pH	pH	Daily during any discharge	3	6.90	7.21	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Daily during any discharge	3	5	24	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A