



NOTES

1. SWIMMING POOL WATER FILTER BACKWASH OR GARBAGE DISPOSAL UNITS SHALL NOT DISCHARGE TO A VACUUM SYSTEM WITHOUT PRIOR WRITTEN APPROVAL FROM HUNTER WATER.
2. ALL SANITARY DRAINAGE SHALL BE INSTALLED TO THE REQUIREMENTS OF AS/NZS 3500.2.
3. VENTS AND OVERFLOW RELIEF GULLIES SHALL BE INSTALLED TO PREVENT INGRESS.

TYPICAL VACUUM SEWER SYSTEM

2	REVISION	G.H.	01.09.2015
1	REVISION by GREG HEANEY	G.H.	12.12.2013
0	CONSTRUCTION ISSUE	G.H.	04.07.2012
REV No.	REVISION	APPROVED	DATE
APPROVED MANAGER ASSET MANAGEMENT HUNTER WATER CORPORATION (H.W.C.)			



STANDARD CONSTRUCTION PRACTICE
SEWERAGE STANDARD
 SERVICE CONNECTION STANDARD
 VACUUM SEWER SYSTEM

CAD FILE NAME: SCP-317 (VACUUM SEWER SYSTEM)
 HWCS
SCP-317
 ISSUED: OCTOBER 2015