



- NOTES
1. HWC PREFERRED OR RECOMMENDED SOLUTION FOR POOL BACKWASH DISCHARGE TO BE THE AIR GAP METHOD.
  2. ALL DRAINAGE WORKS SHALL COMPLY WITH AS/NZS 3500.2.
  3. IF THE GULLY TRAP IS THE ONLY OVERFLOW RELIEF GULLY ENSURE THE GRATE FIXED TO THE RELIEF POINT IS NOT INHIBITED FROM ALLOWING FREE FLOW OF SEWAGE IN THE EVENT OF AN OVERFLOW.

TYPICAL RESIDENTIAL SWIMMING POOL BACKWASH DISCHARGE TO SEWER CONFIGURATION

2	REVISION	G.H.	01.09.2015
1	REVISION by GREG HEANEY	G.H.	12.12.2013
0	CONSTRUCTION ISSUE	G.H.	04.07.2012
REV No.	REVISION	APPROVED	DATE

APPROVED  
MANAGER ASSET MANAGEMENT  
HUNTER WATER CORPORATION (H.W.C.)



STANDARD CONSTRUCTION PRACTICE  
**SEWERAGE STANDARD**

SERVICE CONNECTION STANDARD  
SWIMMING POOL BACKWASH DISCHARGE DETAIL

CAD FILE NAME: TSS-007 SWIM POOL DISCHARGE

HWCS

**TSS-007**

ISSUED: OCTOBER 2015

A3