



- NOTES:**
1. ALL MEASUREMENTS IN MILLIMETRES.
 2. ALL SUCTION & BOOSTER ASSEMBLIES ON FIRE HYDRANTS & FIRE SPRINKLER SERVICES SHALL BE LOCATED DOWNSTREAM OF THE SITE CONTAINMENT BACKFLOW PREVENTION DEVICE AND BE SEPARATE TO ALL DOMESTIC POTABLE WATER SERVICE PIPELINES.
 3. ORIENTATE METER PARALLEL TO OR AT RIGHT ANGLES TO THE FRONT PROPERTY BOUNDARY.
 4. ALL VALVES TO BE AN APPROVED TYPE TO ALLOW BACKFLOW DEVICE TESTING.
 5. ALL ISOLATING VALVES ON "LOW FLOW" BYPASS METER ASSEMBLIES ARE TO BE "LOCKED OPEN" WITH "003" SPECIFICATION LOCKS.
 6. DIN16 FLANGES FOR 100mm ONLY, WHERE ONLY 4 BOLTS CAN BE FITTED

2	REVISION	G.H.	01.09.2015
1	REVISION by GREG HEANEY	G.H.	12.12.2013
0	CONSTRUCTION ISSUE	G.H.	10.07.2012
REV No.	REVISION	APPROVED	DATE
		APPROVED MANAGER ASSET MANAGEMENT HUNTER WATER CORPORATION (H.W.C.)	



STANDARD CONSTRUCTION PRACTICE
WATER SUPPLY STANDARD
 SERVICE CONNECTION STANDARD
 WATER METER CONNECTION TYPE 6
 TEE & VALVE CONNECTION DESIGNATED FIRE /
 SPRINKLER SERVICE

CAD FILE NAME: TSW-008 TYPE 6

HWCS

TSW-008

ISSUED: OCTOBER 2015

A3