



NOTES:

1. WHERE A PROPERTY DOES NOT HAVE FRONTAGE TO A WATERMAIN, AN INITIAL ENQUIRY SHALL BE SUBMITTED TO HUNTER WATER FOR A WATERMAIN EXTENSION
2. SHOULD IT BE ADVISED THAT A NON-STANDARD WATER SERVICE IS AN OPTION THE APPLICANT SHALL SUBMIT A TECHNICAL ASSESSMENT APPLICATION FOR A NON-STANDARD WATER CONNECTION
3. FORMAL APPROVAL FOR THE LOCATION OF THE WATER METER WITHIN PRIVATE PROPERTY IMMEDIATELY ADJACENT THE WATERMAIN CONNECTION (FROM PROPERTY OWNER), AND FOR ALLOWANCE TO LOCATE THE WATER SERVICE PIPEWORK WITHIN THE ROADSIDE RESERVE (FROM RELEVANT ROAD OWNER), SHALL BE SUBMITTED TO HUNTER WATER
4. A SIGNED NON-STANDARD AGREEMENT SHALL BE SUBMITTED TO HUNTER WATER
5. A "WORK AS CONSTRUCTED" PLAN SHALL BE SUBMITTED TO HUNTER WATER IMMEDIATELY ON COMPLETION OF WORKS
6. ALL PLUMBING TO CONFORM TO AS/NZS 3500 - PLUMBING AND DRAINAGE
7. MATERIAL FOR COPPER STANDPIPE TO BE TYPE "B" COPPER TO AS 1432 (COPPER ALLOY FITTINGS TO AS 3688)
8. ORIENTATE METER PARALLEL TO OR AT RIGHT ANGLES TO THE FRONT PROPERTY BOUNDARY
9. ALL PRIVATE PROPERTY SERVICES 20mm TO 25mm SHALL HAVE FLARED JOINTING CONNECTIONS TO THE MAIN TAP AND THE INLET/OUTLET OF THE WATER METER ASSEMBLY ARRANGEMENT
10. WATER METER ASSEMBLY IS TO BE CONSTRUCTED OF COPPER PIPE OR APPROVED EQUIVALENT METALLIC PIPING SYSTEM
11. MINIMUM COVER TO PROPERTY SERVICE AND HOUSE SERVICE AS PER AS/NZS 3500 PLUMBING AND DRAINAGE
12. WATER METER SHALL NOT BE INSTALLED IN BELOW GROUND PITS
13. HUNTER WATER MAY REQUIRE PROTECTIVE BARRIERS AROUND METER FRAMES
14. PRESSURE LIMITING VALVE INSTALLATION ON PRIVATE WATER SERVICES TO MEET REQUIREMENTS AS PER AS/NZS 3500 PLUMBING AND DRAINAGE
15. THE PROPERTY SERVICE WATER METER ASSEMBLY SHALL BE LOCATED:
 - DIRECTLY OPPOSITE THE WATERMAIN TAP AND AT 90° TO THE WATERMAIN
 - FROM 300mm TO 500mm INSIDE THE PROPERTY BOUNDARY
 - WITH ALLOWANCE MADE FOR FUTURE SURFACE LEVEL, FENCING, RETAINING WALLS ADJUSTMENT
 - WATER METERS SHALL BE INSTALLED AT A MINIMUM HEIGHT OF 150mm FROM GROUND LEVEL TO WATER METER BASE

NON STANDARD WATER SERVICE

1	REVISION	G.H.	01.09.2015
0	CONSTRUCTION ISSUE	G.H.	04.07.2012
REV No.	REVISION	APPROVED	DATE
APPROVED MANAGER ASSET MANAGEMENT HUNTER WATER CORPORATION (H.W.C.)			



STANDARD CONSTRUCTION PRACTICE
WATER SUPPLY STANDARD
 SERVICE CONNECTION STANDARD
 NON STANDARD WATER SERVICE

CAD FILE NAME: TSW-011 NON STANDARD WS
 HWCS
TSW-011
 ISSUED: OCTOBER 2015