



BURWOOD BEACH WASTEWATER TREATMENT WORKS - APRIL MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 1683
Date Obtained: 3 May 2017
Date Published: 18 May 2017

Licensee Hunter Water Corporation
36 Honeysuckle Drive
NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 1 Site Code SSL0600		Site Description - Inspection pit down stream of the secondary clarifier and the wet weather bypass chamber											
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 April 2017 to 30 April 2017									
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits	
Aldrin	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
alpha-BHC	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
Arsenic	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
beta-BHC	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
Biochemical Oxygen Demand	milligrams per litre	Every 12 days exactly	3	34	61	52	96	N/A	N/A	N/A	N/A	N/A	
Cadmium	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
Chlordane, total	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
Chromium	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
Copper	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
Dieldrin	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
Endosulfan	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
Endrin	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
gamma-BHC (Lindane)	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
Heptachlor	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
Heptachlor epoxide	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
Hexachlorobenzene	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
Lead	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
Mercury	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
Methoxychlor	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
Nickel	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
Oil and Grease	milligrams per litre	Every 12 days exactly	3	<2	<2	<2	<2	15	-	N/A	N/A	Yes	
p,p-DDD	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
p,p-DDE	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
p,p-DDT	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
Polychlorinated biphenyls	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
Selenium	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
Silver	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	
Total Suspended Solids	milligrams per litre	Every 12 days exactly	3	20	29	25	43	60	-	N/A	N/A	Yes	
Zinc	micrograms per litre	2 times a year	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A	

EPA Id. No. 3 Site Code 5CB0600		Site Description - Sludge pumping station											
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 April 2017 to 30 April 2017									
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits	
Aldrin	micrograms per litre	Monthly	1	<0.010	<0.010	<0.010	<0.010	N/A	N/A	N/A	N/A	N/A	
alpha-BHC	micrograms per litre	Monthly	1	<0.010	<0.010	<0.010	<0.010	N/A	N/A	N/A	N/A	N/A	
Arsenic	micrograms per litre	Weekly	4	18.2	20.8	19.0	27.2	N/A	N/A	N/A	N/A	N/A	
beta-BHC	micrograms per litre	Monthly	1	<0.010	<0.010	<0.010	<0.010	N/A	N/A	N/A	N/A	N/A	
Cadmium	micrograms per litre	Weekly	4	2.6	3.1	2.8	4.0	N/A	N/A	N/A	N/A	N/A	
Chlordane, total	micrograms per litre	Monthly	1	<0.020	<0.020	<0.020	<0.020	N/A	N/A	N/A	N/A	N/A	
Chromium	micrograms per litre	Weekly	4	23.4	30.4	29.0	40.1	N/A	N/A	N/A	N/A	N/A	
Copper	micrograms per litre	Weekly	4	687	804	790	951	N/A	N/A	N/A	N/A	N/A	
Dieldrin	micrograms per litre	Monthly	1	<0.010	<0.010	<0.010	<0.010	N/A	N/A	N/A	N/A	N/A	
Endosulfan	micrograms per litre	Monthly	1	<0.010	<0.010	<0.010	<0.010	N/A	N/A	N/A	N/A	N/A	
Endrin	micrograms per litre	Monthly	1	<0.010	<0.010	<0.010	<0.010	N/A	N/A	N/A	N/A	N/A	
gamma-BHC (Lindane)	micrograms per litre	Monthly	1	<0.010	<0.010	<0.010	<0.010	N/A	N/A	N/A	N/A	N/A	
Heptachlor	micrograms per litre	Monthly	1	<0.005	<0.005	<0.005	<0.005	N/A	N/A	N/A	N/A	N/A	
Heptachlor epoxide	micrograms per litre	Monthly	1	<0.010	<0.010	<0.010	<0.010	N/A	N/A	N/A	N/A	N/A	
Hexachlorobenzene	micrograms per litre	Monthly	1	<0.010	<0.010	<0.010	<0.010	N/A	N/A	N/A	N/A	N/A	
Lead	micrograms per litre	Weekly	4	87.8	126	120	176	N/A	N/A	N/A	N/A	N/A	
Mercury	micrograms per litre	Weekly	4	<0.1	<0.1	<0.1	<0.1	N/A	N/A	N/A	N/A	N/A	
Methoxychlor	micrograms per litre	Monthly	1	<0.010	<0.010	<0.010	<0.010	N/A	N/A	N/A	N/A	N/A	
Nickel	micrograms per litre	Weekly	4	30.6	34.9	32.3	44.5	N/A	N/A	N/A	N/A	N/A	
Nitrogen (ammonia)	milligrams per litre	Every 6 days exactly	5	11.2	46	23	143	N/A	N/A	N/A	N/A	N/A	
Oil and Grease	milligrams per litre	Every 6 days exactly	5	3	29	7	120	N/A	N/A	N/A	N/A	N/A	
p,p-DDD	micrograms per litre	Monthly	1	<0.010	<0.010	<0.010	<0.010	N/A	N/A	N/A	N/A	N/A	
p,p-DDE	micrograms per litre	Monthly	1	<0.010	<0.010	<0.010	<0.010	N/A	N/A	N/A	N/A	N/A	
p,p-DDT	micrograms per litre	Monthly	1	<0.010	<0.010	<0.010	<0.010	N/A	N/A	N/A	N/A	N/A	
Polychlorinated biphenyls	micrograms per litre	Monthly	1	<0.10	<0.10	<0.10	<0.10	N/A	N/A	N/A	N/A	N/A	
Selenium	micrograms per litre	Weekly	4	7.2	8.5	8.9	9.1	N/A	N/A	N/A	N/A	N/A	
Silver	micrograms per litre	Weekly	4	4	6	6	7	N/A	N/A	N/A	N/A	N/A	
Total Solids	percent by weight	Every 6 days exactly	5	0.29	2	0	11	N/A	N/A	N/A	N/A	N/A	
Zinc	micrograms per litre	Weekly	4	2000	2363	2295	2860	N/A	N/A	N/A	N/A	N/A	

EPA Id. No. 10 Site Code 5SG0601		Site Description - Pump well between clarifier and the sludge line											
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 April 2017 to 30 April 2017									
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits	
Total Solids	percent by weight	Every 6 days exactly	5	<0.10	<0.10	<0.10	<0.10	N/A	N/A	N/A	N/A	N/A	

EPA Id. No. 11 Site Code 5CC0600		Site Description - Scum pump well											
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 April 2017 to 30 April 2017									
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits	
Total Solids	percent by weight	Every 6 days exactly	5	<0.10	0.23	<0.10	0.73	N/A	N/A	N/A	N/A	N/A	