



## FARLEY WASTEWATER TREATMENT WORKS - MAY MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 733  
 Date Obtained: 6 June 2017  
 Date Published: 19 June 2017

**Licensee** Hunter Water Corporation  
 36 Honeysuckle Drive  
 NEWCASTLE WEST NSW 2302

### QUALITY MONITORING

EPA Id. No. 1 Site Code 5SL2300		Site Description - Pond No. 2 overflow into Fishery Creek										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting*	Monthly Summary 1 May 2017 to 31 May 2017								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Chlorophyll a	micrograms per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrate+Nitrite (Oxidised Nitrogen)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (Ammonia)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (Total)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
pH	pH	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Phosphorus (Total)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A

\*No samples were collected or analysed during the month as no overflow from the spillway occurred during the month.

EPA Id. No. 3 Site Code 5DE2300		Site Description - Effluent Measurement Flow meter downstream of the ultra-violet disinfection unit										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 May 2017 to 31 May 2017								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Weekly	5	<2	3	2	7	N/A	N/A	N/A	N/A	N/A
Chlorophyll a	micrograms per litre	Weekly	5	1.1	5.7	2.5	15.2	N/A	N/A	N/A	N/A	N/A
Faecal Coliforms	Colony forming units per 100mL	Weekly	5	17	17	17	17	N/A	N/A	N/A	N/A	N/A
Nitrate+Nitrite (Oxidised Nitrogen)	milligrams per litre	Monthly	1	2.2	2.2	2.2	2.2	N/A	N/A	N/A	N/A	N/A
Nitrogen (Ammonia)	milligrams per litre	Weekly	5	0.08	1.2	0.5	4.6	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Monthly	1	<2	<2	<2	<2	N/A	N/A	N/A	N/A	N/A
pH	pH	Weekly	5	7.08	7.31	7.40	7.50	N/A	N/A	N/A	N/A	N/A
Phosphorus (Total)	milligrams per litre	Weekly	5	0.18	0.27	0.30	0.33	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Weekly	5	<1	2	2	3	N/A	N/A	N/A	N/A	N/A

EPA Id. No. 4 Site Code 5OV2300		Site Description - Overflow weir from wet weather storage										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting**	Monthly Summary 1 May 2017 to 31 May 2017								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrate+Nitrite (Oxidised Nitrogen)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (Ammonia)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
pH	pH	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Phosphorus (Total)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A

\*\*No samples were collected or analysed during the month as no overflow from the spillway occurred during the month.