



FARLEY WASTEWATER TREATMENT WORKS - SEPTEMBER MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 733
 Date Obtained: 3 October 2017
 Date Published: 19 October 2017

Licensee Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 1 Site Code 5SL2300		Site Description - Pond No. 2 overflow into Fishery Creek										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting*	Monthly Summary 1 September 2017 to 30 September 2017								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Chlorophyll a	micrograms per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrate+Nitrite (Oxidised Nitrogen)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (Ammonia)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (Total)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
pH	pH	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Phosphorus (Total)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A

*No samples were collected or analysed during the month as no overflow from the spillway occurred during the month.

EPA Id. No. 3 Site Code 5DE2300		Site Description - Effluent Measurement Flow meter downstream of the ultra-violet disinfection unit										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 September 2017 to 30 September 2017								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Weekly	4	<2	2	<2	3	N/A	N/A	N/A	N/A	N/A
Chlorophyll a	micrograms per litre	Weekly	4	<1.0	3.4	2.9	7.0	N/A	N/A	N/A	N/A	N/A
Faecal Coliforms	Colony forming units per 100mL	Weekly	4	17	17	17	17	N/A	N/A	N/A	N/A	N/A
Nitrate+Nitrite (Oxidised Nitrogen)	milligrams per litre	Monthly	1	0.54	0.54	0.54	0.54	N/A	N/A	N/A	N/A	N/A
Nitrogen (Ammonia)	milligrams per litre	Weekly	4	0.05	0.22	0.15	0.51	N/A	N/A	N/A	N/A	N/A
Nitrogen (total)	milligrams per litre	Monthly	1	2.1	2.1	2.1	2.1	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Monthly	1	<2	<2	<2	<2	N/A	N/A	N/A	N/A	N/A
pH	pH	Weekly	4	7.45	7.49	7.49	7.52	N/A	N/A	N/A	N/A	N/A
Phosphorus (Total)	milligrams per litre	Weekly	4	0.09	0.11	0.11	0.14	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Weekly	4	<1	3	3	5	N/A	N/A	N/A	N/A	N/A

EPA Id. No. 4 Site Code 5OV2300		Site Description - Overflow weir from wet weather storage										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting**	Monthly Summary 1 September 2017 to 30 September 2017								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrate+Nitrite (Oxidised Nitrogen)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (Ammonia)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
pH	pH	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Phosphorus (Total)	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A

**No samples were collected or analysed during the month as no overflow from the spillway occurred during the month.