



PAXTON WASTEWATER TREATMENT WORKS - AUGUST MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 3755
 Date Obtained: 4 September 2017
 Date Published: 18 September 2017

Licensee Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 3 Site Code 5PA2805		Site Description - Effluent Discharge Chamber										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 August 2017 to 31 August 2017								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Weekly	5	<2	2	2	3	N/A	N/A	N/A	N/A	N/A
Conductivity	Millisemens per centimetre	Weekly	5	0.775	0.792	0.791	0.813	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Weekly	5	0.27	0.68	0.72	1.00	N/A	N/A	N/A	N/A	N/A
Nitrogen (total)	milligrams per litre	Weekly	5	6.3	7.2	7.0	8.5	N/A	N/A	N/A	N/A	N/A
Phosphorus (total)	milligrams per litre	Weekly	5	0.07	0.12	0.11	0.21	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Weekly	5	<1	<1	<1	1	N/A	N/A	N/A	N/A	N/A
pH	pH	Weekly	5	7.25	7.29	7.29	7.34	N/A	N/A	6.50 - 8.50	7.25 - 7.34	Yes

EPA Id. No. 4 Site Code 5OV1400		Site Description - Overflow weir from wet weather storage pond										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting*	Monthly Summary 1 August 2017 to 31 August 2017								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Faecal Coliforms	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A

*No samples were collected as no discharge occurred during the month