



PAXTON WASTEWATER TREATMENT WORKS - JUNE MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 3755
 Date Obtained: 3 July 2017
 Date Published: 21 July 2017

Licensee Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 3 Site Code 5PA2805		Site Description - Effluent Discharge Chamber										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 June 2017 to 30 June 2017								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Weekly	4	<2	<2	<2	<2	N/A	N/A	N/A	N/A	N/A
Conductivity	Millisemens per centimetre	Weekly	4	0.793	0.817	0.819	0.838	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Weekly	4	0.06	0.08	0.08	0.12	N/A	N/A	N/A	N/A	N/A
Nitrogen (total)	milligrams per litre	Weekly	4	5.9	8.1	8.5	9.7	N/A	N/A	N/A	N/A	N/A
Phosphorus (total)	milligrams per litre	Weekly	4	0.067	0.09	0.07	0.16	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Weekly	4	<1	<1	<1	<1	N/A	N/A	N/A	N/A	N/A
pH	pH	Weekly	4	7.21	7.29	7.31	7.34	N/A	N/A	6.50 - 8.50	7.21 - 7.34	Yes

EPA Id. No. 4 Site Code 5OV1400		Site Description - Overflow weir from wet weather storage pond										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting*	Monthly Summary 1 June 2017 to 30 June 2017								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Faecal Coliforms	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	First 24hrs then weekly	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A

*No samples were collected as no discharge occurred during the month