



## TANILBA BAY WASTEWATER TREATMENT WORKS - APRIL MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 4435  
 Date Obtained: 3 May 2016  
 Date Published: 17 May 2016

**Licensee** Hunter Water Corporation  
 36 Honeysuckle Drive  
 NEWCASTLE WEST NSW 2302

### QUALITY MONITORING

EPA Id. No. 1 Site Code 5SL2900		Site Description - Effluent Distribution Chamber										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 April 2016 to 30 April 2016								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Weekly	4	<2	3	3	3	N/A	N/A	45	3	Yes
Conductivity	microsiemens per centimetre	Monthly	1	725	725	725	725	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Monthly	1	0.32	0.32	0.32	0.32	N/A	N/A	N/A	N/A	N/A
Nitrate + Nitrite (oxidised nitrogen)	milligrams per litre	Monthly	1	6.1	6.1	6.1	6.1	N/A	N/A	N/A	N/A	N/A
Nitrogen (total)	milligrams per litre	Monthly	1	8.2	8.2	8.2	8.2	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Fortnightly	2	<2	<2	<2	<2	N/A	N/A	N/A	N/A	N/A
Phosphorus (total)	milligrams per litre	Monthly	1	7.9	7.9	7.9	7.9	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Weekly	4	6	7	7	8	N/A	N/A	70	8	Yes
pH	pH	Weekly	4	7.3	7.4	7.3	7.5	N/A	N/A	6.5 - 8.5	7.3 - 7.5	Yes

EPA Id. No. 3 Site Code		Site Description - Emergency Overflow from Infiltration Pond										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting #	Monthly Summary 1 April 2016 to 30 April 2016								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Each Overflow Event	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Faecal Coliforms	colony forming units per 100 mL	Each Overflow Event	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Each Overflow Event	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Each Overflow Event	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
pH	pH	Each Overflow Event	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A

# No samples were collected as no overflow occurred during the month