



TANILBA BAY WASTEWATER TREATMENT WORKS - JUNE MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 4435
 Date Obtained: 4 July 2016
 Date Published: 20 July 2016

Licensee Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 1 Site Code 5SL2900		Site Description - Effluent Distribution Chamber										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 June 2016 to 30 June 2016								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Weekly	5	2	3	3	7	N/A	N/A	45	7	Yes
Conductivity	microsiemens per centimetre	Monthly	1	1880	1880	1880	1880	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Monthly	1	0.64	0.64	0.64	0.64	N/A	N/A	N/A	N/A	N/A
Nitrate + Nitrite (oxidised nitrogen)	milligrams per litre	Monthly	1	13.9	13.9	13.9	13.9	N/A	N/A	N/A	N/A	N/A
Nitrogen (total)	milligrams per litre	Monthly	1	14.6	14.6	14.6	14.6	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Fortnightly	3	<2	<2	<2	<2	N/A	N/A	N/A	N/A	N/A
Phosphorus (total)	milligrams per litre	Monthly	1	4.1	4.1	4.1	4.1	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Weekly	5	<1	5	5	7	N/A	N/A	70	7	Yes
pH	pH	Weekly	5	7.1	7.3	7.3	7.4	N/A	N/A	6.5 - 8.5	7.1 - 7.4	Yes

EPA Id. No. 3 Site Code		Site Description - Emergency Overflow from Infiltration Pond										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting #	Monthly Summary 1 June 2016 to 30 June 2016								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Each Overflow Event	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Faecal Coliforms	colony forming units per 100 mL	Each Overflow Event	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Each Overflow Event	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Each Overflow Event	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
pH	pH	Each Overflow Event	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A

No samples were collected as no overflow occurred during the month