



Chichester Raw Water Quality Data - July 2017

Chichester Raw Water is not suitable for drinking.
Chichester Raw Water is treated at Dungog Water Treatment Plant (WTP) before supplying treated drinking water to customers.

Turbidity, E. coli and Chlorine Results for Chichester Raw Water at Dusodie#

Analyte	Unit	ADWG guideline value*	Sample Date (week beginning)				
			3/07/2017	10/07/2017	17/07/2017	24/07/2017	31/07/2017
E. coli	MPN/100mL	should not be detected in 100mL	<1	<1	<1	<1	<1
Turbidity	NTU	5	2.7	2.9	2.4	2.5	2.2
Chlorine	mg/L	5	0.6	0.67	0.69	0.71	0.69

Samples are collected from Chichester Trunk Gravitation Main (CTGM) at Dusodie prior to treatment by Dungog WTP.

*Australian Drinking Water Guidelines 2011 (ADWG) guideline values are applicable to drinking water samples

Potentially Toxic Blue Green Algae Results for Chichester Raw Water at Screens^

Potentially Toxic Blue Green Algae	Unit	ADWG Alert Levels	Sample Date (week beginning)			
			4/07/2017	11/07/2017	18/07/2017	25/07/2017
Dolichospermum	cells/mL	20,000	0	0	55	0
Microcystis	cells/mL	6,500	10	20	30	0

^ Samples are collected from Chichester Screens prior to treatment by Dungog WTP.

Protozoa Results for Chichester Raw Water at Dungog WTP**

Protozoa	Unit	Sample Date (week beginning)
		1/05/2017
Cryptosporidium	Oocysts/10L	<1
Giardia	Cysts/10L	<1

** Samples are collected from CTGM at Dungog WTP prior to treatment by Dungog WTP. Robust treatment processes are in place at Dungog WTP for removal of cryptosporidium and giardia.