



## Chichester Raw Water Quality Data - January 2023

### Chichester Raw Water is not suitable for drinking.

Chichester Raw Water is treated at Dungog Water Treatment Plant (WTP) before supplying treated drinking water to customers.

#### Turbidity and Chlorine Results for Chichester Raw Water at Dusodie#

Analyte	Unit	ADWG guideline value*	Sample Date				
			3/01/2023	9/01/2023	16/01/2023	23/01/2023	30/01/2023
Turbidity	NTU	5	2.67	4.8	3.64	2.98	2.23
Chlorine**	mg/L	5	0	0	0.1	0.3	0

#### E. coli Results for Chichester Raw Water at Dam Offtake Screens^

Analyte	Unit	ADWG guideline value*	Sample Date					
			4/01/2023	9/01/2023	13/01/2023	16/01/2023	23/01/2023	30/01/2023
E. coli	MPN/100mL	should not be detected in 100mL	<1	82	10	<1	<1	1

#### Potentially Toxic Blue Green Algae Results for Chichester Raw Water at Dam Offtake Screens^

Potentially Toxic Blue Green Algae	Unit	ADWG Alert Levels	Sample Date				
			4/01/2023	9/01/2023	16/01/2023	23/01/2023	30/01/2023
Dolichospermum	cells/mL	20,000	0	0	0	0	0
Microcystis	cells/mL	6,500	0	0	0	0	0

#### Protozoa Results for Chichester Raw Water at Dam Offtake Screens^

Protozoa	Unit	Sample Date					
		4/01/2023	9/01/2023	13/01/2023	16/01/2023	23/01/2023	30/01/2023
Cryptosporidium	Oocysts/L	0	< 0.1	< 0.1	0	0	0
Giardia	Cysts/L	0	< 0.1	< 0.1	0	0	0

# Samples are collected from Chichester Trunk Gravity Main (CTGM) at Dusodie prior to treatment by Dungog WTP.

\* Australian Drinking Water Guidelines 2011 (ADWG) guideline values are applicable to drinking water samples.

\*\* The Chlorinator is only operated periodically to assist in removal of dissolved Manganese.

^ Samples are collected from Chichester Screens prior to treatment by Dungog WTP.