



## Chichester Raw Water Quality Data - July 2023

### Chichester Raw Water is not suitable for drinking.

Chichester Raw Water is treated at Dungog Water Treatment Plant (WTP) before supplying treated drinking water to customers.

#### Turbidity and Chlorine Results for Chichester Raw Water at Dusodie#

Analyte	Unit	ADWG guideline value*	Sample Date				
			3/07/2023	10/07/2023	17/07/2023	24/07/2023	31/07/2023
Turbidity	NTU	5	1.81	2.43	1.9	2.59	2.18
Chlorine**	mg/L	5	0.05	0.03	0	0	0.04

#### E. coli Results for Chichester Raw Water at Dam Offtake Screens^

Analyte	Unit	ADWG guideline value*	Sample Date				
			3/07/2023	10/07/2023	17/07/2023	24/07/2023	31/07/2023
E. coli	MPN/100mL	should not be detected in 100mL	<1	2	<1	2	2

#### Potentially Toxic Blue Green Algae Results for Chichester Raw Water at Dam Offtake Screens^

Potentially Toxic Blue Green Algae	Unit	ADWG Alert Levels	Sample Date				
			3/07/2023	10/07/2023	17/07/2023	24/07/2023	31/07/2023
Dolichospermum	cells/mL	20,000	ND	<5	<5	<5	<5
Microcystis	cells/mL	6,500	ND	<5	<5	<5	<5

#### Protozoa Results for Chichester Raw Water at Dam Offtake Screens^

Protozoa	Unit	Sample Date				
		3/07/2023	10/07/2023	17/07/2023	24/07/2023	31/07/2023
Cryptosporidium	Oocysts/L	<0.1	0	0	0	0
Giardia	Cysts/L	<0.1	0	0	0	0

# Samples are collected from Chichester Trunk Gravity Main (CTGM) at Dusodie prior to treatment by Dungog WTP.

\* Australian Drinking Water Guidelines 2011 (ADWG) guideline values are applicable to drinking water samples.

\*\* The Chlorinator is only operated periodically to assist in removal of dissolved Manganese.

^ Samples are collected from Chichester Screens prior to treatment by Dungog WTP.