



## Chichester Raw Water Quality Data - July 2024

### Chichester Raw Water is not suitable for drinking.

Chichester Raw Water is treated at Dungog Water Treatment Plant (WTP) before supplying treated drinking water to customers.

#### Turbidity and Chlorine Results for Chichester Raw Water at Dusodie#

Analyte	Unit	ADWG guideline value*	Sample Date				
			1/07/2024	8/07/2024	15/07/2024	22/07/2024	29/07/2024
Turbidity	NTU	5	9.89	11.7	9.2	8.32	7.54
Chlorine**	mg/L	5	0.05	0.04	0.05	0.06	0.18

#### E. coli Results for Chichester Raw Water at Dam Offtake Screens^

Analyte	Unit	ADWG guideline value*	Sample Date	
			1/07/2024	15/07/2024
E. coli	MPN/100mL	should not be detected in 100mL	10	6

#### Potentially Toxic Blue Green Algae Results for Chichester Raw Water at Dam Offtake Screens^

Potentially Toxic Blue Green Algae	Unit	ADWG Alert Levels	Sample Date	
			1/07/2024	15/07/2024
Dolichospermum	cells/mL	20,000	<5	<5
Microcystis	cells/mL	6,500	<5	<5

#### Protozoa Results for Chichester Raw Water at Dam Offtake Screens^

Protozoa	Unit	Sample Date
		1/07/2024
Cryptosporidium	Oocysts/L	<0.1
Giardia	Cysts/L	<0.1

# Samples are collected from Chichester Trunk Gravity Main (CTGM) at Dusodie prior to treatment by Dungog WTP.

\* Australian Drinking Water Guidelines 2011 (ADWG) guideline values are applicable to drinking water samples.

\*\* The Chlorinator is only operated periodically to assist in removal of dissolved Manganese.

^ Samples are collected from Chichester Screens prior to treatment by Dungog WTP.

^^ Samples are averaged from multiple