



## Drinking Water Quality Summary - April 2016

Hunter Water provides safe and reliable drinking water to over half a million customers in the Lower Hunter. The drinking water we supply is routinely tested throughout our water supply systems. Results are based on samples representative of water supplied to customers' taps. Results for microbiological and key physical/chemical parameters are summarised below:

### Whole of Hunter Water

#### Whole of Hunter Water - key health analytes

Analyte	Units of measure	ADWG health guideline value	Performance standard (assessment over previous 12 months)		% of E. coli results < 1 over the last 12 months	Met performance standard
<i>E. coli</i>	MPN/100mL	Should not be detected in 100mL	At least 98% of test results <1		99.94%	Yes

Analyte	Units of Measure	ADWG health guideline value	Performance standard (assessment over previous 12 months)	Average for Month	95th Percentile over the last 12 months	Met performance standard
Fluoride	mg/L	1.5	95th percentile of test results less than respective ADWG health guideline value	0.57	0.99	Yes
Chlorine	mg/L	5		0.68	1.49	Yes
Copper	mg/L	2		0.002	0.020	Yes
Lead	mg/L	0.01		0.000	0.001	Yes
Manganese	mg/L	0.5		0.007	0.014	Yes
Trihalomethanes	mg/L	0.25		0.109	0.162	Yes

#### Whole of Hunter Water - key aesthetic analytes

Analyte	Units of Measure	ADWG aesthetic guideline value	Performance standard (assessment over previous 12 months)	Average for Month	12 month average result	Met performance standard
Iron	mg/L	0.3	Average of test results less than respective ADWG aesthetic guideline value	0.033	0.030	Yes
Aluminium	mg/L	0.2		0.056	0.054	Yes
Copper	mg/L	1		0.002	0.006	Yes
Zinc	mg/L	3		0.004	0.004	Yes
Turbidity	NTU	5		0.2	0.3	Yes
True colour	HU	15	5	5	Yes	
pH	pH units	6.5-9.2	Average of test results between 6.5 - 9.2 pH units	7.72	7.59	Yes

Brief explanation of key parameters:

or for more detail see:

Map showing water quality zones:

[Key Physical, Chemical and Microbiological Parameters](#)

[Australian Drinking Water Guidelines 2011](#)

[Water Quality Zones at Hunter Water](#)

# Water Quality Zones

## Chichester Zone - key health analytes

Analyte	Units of Measure	ADWG health guideline value	Performance standard (assessment over previous 12 months)		% of E. coli results < 1 over the last 12 months	Met performance standard
---------	------------------	-----------------------------	---	--	--	--------------------------

<i>E. coli</i>	MPN/100mL	Should not be detected in 100mL	At least 98% of test results <1		100.00%	Yes
----------------	-----------	---------------------------------	---------------------------------	--	---------	-----

Analyte	Units of Measure	ADWG health guideline value	Performance standard (assessment over previous 12 months)	Average for Month	95th Percentile over the last 12 months	Met performance standard
Fluoride	mg/L	1.5	95th percentile of test results less than respective ADWG health guideline value	0.89	0.94	Yes
Chlorine	mg/L	5		0.47	1.43	Yes
Copper	mg/L	2		0.001	0.008	Yes
Lead	mg/L	0.01		0.000	0.001	Yes
Manganese	mg/L	0.5		0.010	0.015	Yes
Trihalomethanes	mg/L	0.25		0.140	0.160	Yes

## Chichester Zone – key aesthetic analytes

Analyte	Units of Measure	ADWG aesthetic guideline value	Performance standard (assessment over previous 12 months)	Average for Month	12 month average result	Met performance standard
Iron	mg/L	0.3	Average of test results less than respective ADWG aesthetic guideline value	0.020	0.025	Yes
Aluminium	mg/L	0.2		0.047	0.052	Yes
Copper	mg/L	1		0.001	0.004	Yes
Zinc	mg/L	3		0.003	0.004	Yes
Turbidity	NTU	5		0.3	0.3	Yes
True colour	HU	15		5	5	Yes
pH	pH units	6.5-9.2	Average of test results between 6.5 - 9.2 pH units	7.78	7.65	Yes

## Grahamstown Zone - key health analytes

Analyte	Units of Measure	ADWG health guideline value	Performance standard (assessment over previous 12 months)	Average for Month	% of E. coli results < 1 over the last 12 months	Met performance standard
---------	------------------	-----------------------------	---	-------------------	--	--------------------------

<i>E. coli</i>	MPN/100mL	Should not be detected in 100mL	At least 98% of test results <1		99.89%	Yes
----------------	-----------	---------------------------------	---------------------------------	--	--------	-----

Analyte	Units of Measure	ADWG health guideline value	Performance standard (assessment over previous 12 months)	Average for Month	95th Percentile over the last 12 months	Met performance standard
Fluoride	mg/L	1.5	95th percentile of test results less than respective ADWG health guideline value	0.17	1.01	Yes
Chlorine	mg/L	5		0.78	1.52	Yes
Copper	mg/L	2		0.002	0.009	Yes
Lead	mg/L	0.01		0.000	0.001	Yes
Manganese	mg/L	0.5		0.005	0.014	Yes
Trihalomethanes	mg/L	0.25		0.121	0.170	Yes

## Grahamstown Zone – key aesthetic analytes

Analyte	Units of Measure	ADWG aesthetic guideline value	Performance standard (assessment over previous 12 months)	Average for Month	12 month average result	Met performance standard
Iron	mg/L	0.3	Average of test results less than respective ADWG aesthetic guideline value	0.023	0.031	Yes
Aluminium	mg/L	0.2		0.073	0.078	Yes
Copper	mg/L	1		0.002	0.005	Yes
Zinc	mg/L	3		0.002	0.003	Yes
Turbidity	NTU	5		0.2	0.3	Yes
True colour	HU	15		5	5	Yes
pH	pH units	6.5-9.2	Average of test results between 6.5 - 9.2 pH units	7.72	7.57	Yes

# Water Quality Zones

## Lemon Tree Passage Zone - key health analytes

Analyte	Units of Measure	ADWG health guideline value	Performance standard (assessment over previous 12 months)	Average for Month	% of E. coli results < 1 over the last 12 months	Met performance standard
---------	------------------	-----------------------------	---	-------------------	--	--------------------------

<i>E. coli</i>	MPN/100mL	Should not be detected in 100mL	At least 98% of test results <1		100.00%	Yes
----------------	-----------	---------------------------------	---------------------------------	--	---------	-----

Analyte	Units of Measure	ADWG health guideline value	Performance standard (assessment over previous 12 months)	Average for Month	95th Percentile over the last 12 months	Met performance standard
---------	------------------	-----------------------------	---	-------------------	---	--------------------------

Fluoride	mg/L	1.5	95th percentile of test results less than respective ADWG health guideline value	0.74	1.01	Yes
Chlorine	mg/L	5		0.84	1.30	Yes
Copper	mg/L	2		0.004	0.009	Yes
Lead	mg/L	0.01		0.000	0.001	Yes
Manganese	mg/L	0.5		0.003	0.008	Yes
Trihalomethanes	mg/L	0.25		0.100	0.138	Yes

## Lemon Tree Passage Zone - key aesthetic analytes

Analyte	Units of Measure	ADWG aesthetic guideline value	Performance standard (assessment over previous 12 months)	Average for Month	12 month average result	Met performance standard
---------	------------------	--------------------------------	---	-------------------	-------------------------	--------------------------

Iron	mg/L	0.3	Average of test results less than respective ADWG aesthetic guideline value	0.035	0.030	Yes
Aluminium	mg/L	0.2		0.039	0.034	Yes
Copper	mg/L	1		0.004	0.006	Yes
Zinc	mg/L	3		0.009	0.006	Yes
Turbidity	NTU	5		0.2	0.2	Yes
True colour	HU	15		5	5	Yes

pH	pH units	6.5-9.2	Average of test results between 6.5 - 9.2 pH units	7.58	7.56	Yes
----	----------	---------	--	------	------	-----

## Anna Bay / Nelson Bay Zone - key health analytes

Analyte	Units of Measure	ADWG health guideline value	Performance standard (assessment over previous 12 months)	Average for Month	% of E. coli results < 1 over the last 12 months	Met performance standard
---------	------------------	-----------------------------	---	-------------------	--	--------------------------

<i>E. coli</i>	MPN/100mL	Should not be detected in 100mL	At least 98% of test results <1		100.00%	Yes
----------------	-----------	---------------------------------	---------------------------------	--	---------	-----

Analyte	Units of Measure	ADWG health guideline value	Performance standard (assessment over previous 12 months)	Average for Month	95th Percentile over the last 12 months	Met performance standard
---------	------------------	-----------------------------	---	-------------------	---	--------------------------

Fluoride	mg/L	1.5	95th percentile of test results less than respective ADWG health guideline value	0.53	0.83	Yes
Chlorine	mg/L	5		0.69	1.39	Yes
Copper	mg/L	2		0.002	0.022	Yes
Lead	mg/L	0.01		0.000	0.000	Yes
Manganese	mg/L	0.5		0.009	0.009	Yes
Trihalomethanes	mg/L	0.25		0.059	0.099	Yes

## Anna Bay / Nelson Bay Zone - key aesthetic analytes

Analyte	Units of Measure	ADWG aesthetic guideline value	Performance standard (assessment over previous 12 months)	Average for Month	12 month average result	Met performance standard
---------	------------------	--------------------------------	---	-------------------	-------------------------	--------------------------

Iron	mg/L	0.3	Average of test results less than respective ADWG aesthetic guideline value	0.128	0.037	Yes
Aluminium	mg/L	0.2		0.061	0.054	Yes
Copper	mg/L	1		0.002	0.007	Yes
Zinc	mg/L	3		0.005	0.005	Yes
Turbidity	NTU	5		0.3	0.2	Yes
True colour	HU	15		5	5	Yes

pH	pH units	6.5-9.2	Average of test results between 6.5 - 9.2 pH units	7.60	7.51	Yes
----	----------	---------	--	------	------	-----

