



NOTES:

1. THIS PLAN SHOWS TWO TYPICAL LAYOUTS FOR ON PROPERTY PRESSURE SEWER INFRASTRUCTURE. IT ALSO SHOWS TYPICAL DETAILS TO BE SHOWN ON STREET RETICULATION PLANS.
2. THE COLLECTION TANK IS TO BE LOCATED ON THE LOWER SIDE OF THE PROPERTY AT A DISTANCE OF BETWEEN 1.5M TO 5M TO THE OUTER EDGE OF THE TANK LID FROM THE SIDE PROPERTY BOUNDARY.
3. CONTROL/ALARM PANEL TO BE LOCATED WITHIN 10M OF COLLECTION TANK WITH DIRECT LINE OF SIGHT. WHERE THIS IS NOT POSSIBLE MOUNT ON A FREE STANDING POST POSITIONED WITHIN 4M OF THE CENTRE OF THE COLLECTION TANK. REFER TO DRAWING PSS-1104-V FOR POST DETAILS.
4. THE COLLECTION TANK IS TO BE LOCATED AT THE FRONT OF THE PROPERTY AT A MAXIMUM DISTANCE OF 3M TO THE CENTRE OF THE TANK FROM THE COUNCIL APPROVED BUILDING SET BACK FROM THE PROPERTY BOUNDARY. REFER TO WSA07 CLAUSE 7.3 AND HWC WSA07 SUPPLEMENT 7.3.
5. PRESSURE SEWER RETICULATION PLANS TO SHOW ALL FITTINGS MARKED WITH THE FOLLOWING ABBREVIATIONS; STOP VALVES 'SV', FLOW METERS 'FM', FLUSHING POINT 'FP', AIR VALVES "AV".

LEGENDS:

	CONTROL/ALARM PANEL
	FLUSHING POINT
	ISOLATION STOP VALVE
	PROPERTY BOUNDARY KIT
	COLLECTION TANK/PUMPING UNIT
	SWITCHBOARD
	PUMP CONTROL/POWER CABLE
	PRESSURE RETICULATION SEWER CHAINAGE
	PRESSURE LATERAL SEWER
	PROPERTY DISCHARGE LINE
	TIES
	PRESSURE SEWER RETICULATION
	SANITARY DRAIN TO COLLECTION TANK

WITH ACKNOWLEDGEMENT TO 	PRESSURE SEWERAGE CODE OF AUSTRALIA		NOT TO SCALE	
	DESIGN LAYOUT TYPICAL LOCALITY AND SITE PLAN		PSS-1100-V	
	ISSUED 2017	VERSION 2.0	© COPYRIGHT	